

Department of Public Works **Engineering Division** Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115 210 Martin Luther King, Jr. Boulevard Madison, Wisconsin 53703 Phone: (608) 266-4751 Fax: (608) 264-9275 <u>engineering@cityofmadison.com</u> www.cityofmadison.com/engineering

Deputy City Engineer Gregory T. Fries, P.E.

Deputy Division Manager Kathleen M. Cryan

Principal Engineer 2 Christopher J. Petykowski, P.E. John S. Fahrney, P.E.

Principal Engineer 1 Christina M. Bachmann, P.E. Mark D. Moder, P.E. Janet Schmidt, P.E.

Facilities & Sustainability Jeanne E. Hoffman, Manager Bryan Cooper, Principal Architect

Mapping Section Manager Eric T. Pederson, P.S.

> Financial Manager Steven B. Danner-Rivers

## NOTICE OF ADDENDUM ADDENDUM NO. 1

# CONTRACT NO. 8312, PROJECT NO. 11871 SOUTH POINT ROAD ASSESSMENT DISTRICT – 2019

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

PLANS:

**REMOVE** Remove Sheet U-3.

INSERT Insert Sheet U-3 (Revised 6-4-19) Heavy riprap and filter fabric added to front of culvert apron ends.

## **SPECIAL PROVISIONS:**

ADD

## BID ITEM 20230: HEAVY RIPRAP – GLACIAL FIELD STONE

#### DESCRIPTION

Work under this item includes all equipment, materials, labor, and incidentals required to provide and install glacial field stone as shown in the plan set at the three (3) 42" apron endwalls at the west side of South Point Rd and described in these Special Provisions. The stone shall be sized and placed in accordance with Article 212 of the Standard Specifications. All riprap shall be underlain with Geotextile Filter Fabric Type HR, which will be paid for under Bid Item 20233.

The material shall be comprised of rounded, durable, glacial till that has been sorted for size and is not susceptible to freeze-thaw degradation. Crushed, blasted, or "made" stone will not be permitted on site.

Prior to placement, the Contractor shall submit sourcing information to the Project Engineer or

June 4, 2019

June 4, 2019 Page 2

Construction Engineer. The Project Engineer, or their representative, may choose to evaluate the material at the source prior to acceptance.

Filter fabric shall be placed in a manner that prevents excess material from showing beyond the placed riprap. Riprap shall be placed such that the top surface of the stone is at or below the apron endwall elevation.

It is estimated that 35 C.Y. of excavation will be required to install Heavy Riprap. This excavation quantity is included in Bid Item 20101.

### METHOD OF MEASUREMENT

Heavy Riprap – Glacial Field Stone shall be measured per Ton of material provided, transported, and placed on site. Tonnage shall be determined by truck tickets or by a method mutually agreed upon by the Contractor and Construction Engineer.

### **BASIS OF PAYMENT**

Heavy Riprap – Glacial Field Stone shall be measured as described above and shall be paid for at the contract unit price which shall be considered full compensation for all work, materials, equipment, and incidentals necessary to prepare the riprap site; and source, transport, and place stone as defined in the plan set and these Special Provisions.

#### PROPOSAL

A summary of the change to the proposal is as follows:

Action	Bid Item	Description
REVISE	20101	EXCAVATION CUT
		HEAVY RIPRAP –
ADD	20230	GLACIAL FIELD
		STONE
ADD	20233	RIPRAP FILTER
		FABRIC, TYPE HR

Please see Bid Express for revised bid item quantities.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

#### http://www.bidexpress.com

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,

Robert F. Phillips, P.E., City Engineer

