



Department of Public Works  
**Engineering Division**  
Robert F. Phillips, P.E., City Engineer  
City-County Building, Room 115  
210 Martin Luther King, Jr. Boulevard  
Madison, Wisconsin 53703  
Phone: (608) 266-4751  
Fax: (608) 264-9275  
[engineering@cityofmadison.com](mailto:engineering@cityofmadison.com)  
[www.cityofmadison.com/engineering](http://www.cityofmadison.com/engineering)

**Deputy City Engineer**  
Gregory T. Fries, P.E.  
**Deputy Division Manager**  
Kathleen M. Cryan  
**Principal Engineer 2**  
John S. Fahrney, P.E.  
Christopher J. Petykowski, P.E.  
Janet Schmidt, P.E.  
**Principal Engineer 1**  
Christina M. Bachmann, P.E.  
Mark D. Moder, P.E.  
James M. Wolfe, P.E.  
**Facilities & Sustainability**  
Bryan Cooper, Principal Architect  
**Mapping Section Manager**  
Eric T. Pederson, P.S.  
**Financial Manager**  
Steven B. Danner-Rivers

July 6, 2020

**NOTICE OF ADDENDUM  
ADDENDUM NO. 2**

**CONTRACT NO. 8850, PROJECT NO. 11971  
WARNER BEACH PARK SHELTER**

This addendum is issued to modify, explain or correct the original Drawings, Specifications, or Contract Documents marked as ***WARNER BEACH PARK SHELTER, City of Madison, Contract #8850, as issued on June 12, 2020*** and is hereby made a part of the contract documents.

This addendum consists of the following documents:

**None**

1. **GENERAL CONTRACT CONDITIONS**

None

2. **GENERAL QUESTIONS AND ANSWERS**

None

3. **“NOT” ACCEPTABLE EQUIVALENTS**

A. 08 41 13 Aluminum Framed Entrances and Storefronts

i. Product: DeSCo i65 Series Fixed Windows

**This item was accepted in Addendum #1 and is now removed from acceptable equivalents as it cannot meet required lengths and joint types.**

4. **SPECIFICATIONS**

None

5. **DRAWINGS**

None

6. **PROPOSAL**

No Revisions

Revise and amend the contract document(s) for the above project as stated in this addendum,

otherwise, the original document shall remain in effect.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,

A handwritten signature in blue ink, appearing to read "Robt F. Phillips", is written above a solid black horizontal line.

On behalf of Robert F. Phillips, P.E., City Engineer

Cc: Greg Fries, Kathy Cryan