



Department of Public Works  
**Engineering Division**  
 Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115  
 210 Martin Luther King, Jr. Boulevard  
 Madison, Wisconsin 53703  
 Phone: (608) 266-4751  
 Fax: (608) 264-9275  
[engineering@cityofmadison.com](mailto:engineering@cityofmadison.com)  
[www.cityofmadison.com/engineering](http://www.cityofmadison.com/engineering)

**Assistant City Engineer**  
 Gregory T. Fries, P.E.  
 Kathleen M. Cryan

**Principal Engineer 2**  
 Christopher J. Petykowski, P.E.  
 John S. Fahrney, P.E.

**Principal Engineer 1**  
 Christina M. Bachmann, P.E.  
 Mark D. Moder, P.E.  
 Janet Schmidt, P.E.

**Facilities & Sustainability**  
 Jeanne E. Hoffman, Manager  
 Bryan Cooper, Principal Architect

**Mapping Section Manager**  
 Eric T. Pederson, P.S.

**Financial Manager**  
 Steven B. Danner-Rivers

April 30, 2019

**NOTICE OF ADDENDUM  
 ADDENDUM 2  
 CONTRACT NO. 9412  
 WEST ELDERBERRY SANITARY SEWER INTERCEPTOR - 2019**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

**SPECIAL PROVISIONS:**

EDITS TO PAGE D-1:

ADD TO END OF ARTICLE 105.12 COOPERATION BY THE CONTRACTOR:

Alliant Energy owns the overhead power lines running parallel to Mineral Point Road. The contact for Alliant Energy for this project is Nicholas Dachniwskyj who can be contacted at (608) 845-1143 or [nicholasdachniwskyj@alliantenergy.com](mailto:nicholasdachniwskyj@alliantenergy.com). Alliant Energy shall be contact 72 hours prior to any work that will occur within 10 feet of the overhead power lines, as Alliant will need to de-energize the lines in order for the work to occur. If overhead poles need to be supported, the Contractor shall contact Alliant Energy a minimum of 48 hours prior.

MODIFY FIRST SENTENCE OF ARTICLE 104 SCOPE OF WORK:

This project involves the installation of ~~1428.5 feet of 10 inch~~, 970.5 feet of 12 inch, and 1611.5' of 15 inch diameter sewer.

**PROPOSAL:**

BID ITEM	DESCRIPTION	ACTION
20221	TOPSOIL	MODIFY
20701	TERRACE SEEDING	MODIFY
21014	CLEAR STONE BERM (DITCH CHECK)	MODIFY
21022	SILT FENCE - PROVIDE, INSTALL & MAINTAIN	MODIFY
21023	SILT FENCE - REMOVE & RESTORE	MODIFY
21063	EROSION MATTING, CLASS I, TYPE A - ORGANIC	MODIFY

April 30, 2019

Page 2

40203	HMA PAVEMENT 3 MT 58-28 S	DELETE
40211	TACK COAT	DELETE
40301	FULL WIDTH GRINDING	DELETE
50103	RECONSTRUCT BENCH AND FLOWLINE(S)	ADD
50212	SELECT BACKFILL FOR SANITARY SEWER	MODIFY
50226	UTILITY TRENCH PATCH TYPE III	DELETE
50302	10 INCH PVC SANITARY SEWER PIPE	DELETE
50701	4' DIA. SANITARY SAS	MODIFY
50791	SANITARY SEWER TAP	MODIFY
50797	EXTERNAL SEWER ACCESS STRUCTURE JOINT SEAL	ADD
60800	PAVEMENT MARKING EPOXY, LINE 4-INCH	DELETE
60802	PAVEMENT MARKING EPOXY, LINE, 6-INCH	DELETE

**PLAN SET:**

P1, P2, & P3: Revised sheet P1 to show removal of pipe along Mineral Point Rd. Sheets P2 & P3 are removed from the plan set.

P10: Added external sewer access structure wraps. Removed structures SAS #100 through #104 and removed all 10" sanitary pipe along Mineral Point Rd.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,



Robert F. Phillips, P.E., City Engineer



# SANITARY SEWER SCHEDULE

\*REVISED 4/30/2019

WEST ELDERBERRY SANITARY  
SEWER INTERCEPTOR - 2019

SHEET NO.  
P-10

PROJECT NO. 11842  
SANITARY SEWER SCHEDULE  
CITY OF MADISON

## PROPOSED SANITARY STRUCTURES

SAS NO.	STATION	LOCATION (OFFSET)	TOP OF CASTING	E.I.	DEPTH	NOTES
<b>EASEMENT</b>						
* SAS #1	101+15.00	CL	1064.88	1049.43	15.45	[1], [2], [3]
* SAS #2	105+90.13	CL	1080.04	1058.37	21.67	[1], [3], FIVE FOOT DIAMETER
* SAS #3	107+50.13	CL	1080.26	1059.27	20.99	[1], [3]
* SAS #4	108+91.65	LT-3.00	1079.18	1060.08	19.10	[1], [3]
* SAS #5	111+90.05	CL	1076.50	1061.68	14.82	[1], [3]
* SAS #6	115+63.15	CL	1077.99	1063.64	14.35	[1], [3]
* SAS #7	117+37.05	CL	1080.64	1067.21	13.43	[1], [3]
* SAS #8	119+22.60	CL	1082.94	1071.02	11.92	[1], [3]
* SAS #9	121+82.69	RT-3.05	1092.91	1076.31	16.60	[1], [3]
* SAS #10	124+18.78	CL	1102.53	1081.95	20.58	[1], [3]
* SAS #11	125+34.29	CL	1099.04	1084.94	14.10	[1], [3]
<b>MINERAL POINT RD</b>						
<del>* SAS #100</del>	<del>13+24.95</del>	<del>RT 6.50</del>	<del>1063.79</del>	<del>1044.44</del>	<del>19.35</del>	<del>[2]</del>
<del>* SAS #101</del>	<del>16+49.95</del>	<del>RT 6.50</del>	<del>1066.27</del>	<del>1049.40</del>	<del>16.87</del>	<del>[2]</del>
<del>* SAS #102</del>	<del>20+01.95</del>	<del>RT 6.50</del>	<del>1071.56</del>	<del>1054.78</del>	<del>16.78</del>	<del>[2]</del>
<del>* SAS #103</del>	<del>22+11.95</del>	<del>RT 6.50</del>	<del>1076.02</del>	<del>1061.19</del>	<del>14.83</del>	<del>[2]</del>
<del>* SAS #104</del>	<del>24+23.95</del>	<del>RT 6.50</del>	<del>1080.72</del>	<del>1067.65</del>	<del>13.07</del>	<del>[2]</del>

## PROPOSED SANITARY PIPES

FROM (DNSTM)	TO (UPSTM)	DWNSTRM E.I.	UPSTRM E.I.	PLAN (PAY) LGTH (FT)	SLOPE (%)	PIPE SIZE	PVC TYPE	NOTES
<b>EASEMENT</b>								
* EX SAS #1455-001	SAS #1	1042.09	1049.43	163	4.50%	15"	SDR-26	[4]
SAS #1	SAS #2	1049.53	1058.37	475	1.86%	15"	SDR-26	-
SAS #2	SAS #3	1058.47	1059.27	160	0.50%	15"	SDR-26	-
SAS #3	SAS #4	1059.37	1060.08	141.5	0.50%	15"	SDR-26	-
SAS #4	SAS #5	1060.18	1061.68	299	0.50%	15"	SDR-26	-
SAS #5	SAS #6	1061.78	1063.64	373	0.50%	15"	SDR-26	-
SAS #6	SAS #7	1063.74	1067.21	173.5	2.00%	12"	SDR-26	-
SAS #7	SAS #8	1067.31	1071.02	185.5	2.00%	12"	SDR-26	-
SAS #8	SAS #9	1071.12	1076.31	260	2.00%	12"	SDR-26	-
SAS #9	SAS #10	1076.41	1081.95	236	2.35%	12"	SDR-26	-
SAS #10	SAS #11	1082.05	1084.94	115.5	2.50%	12"	SDR-26	-
SAS #11	EX SAS #1	1085.04	1093.50	239.5	3.53%	10"	SDR-26	-
<b>MINERAL POINT RD</b>								
<del>* EX SAS #1455-001</del>	<del>SAS #100</del>	<del>1043.09</del>	<del>1044.44</del>	<del>90</del>	<del>1.50%</del>	<del>10"</del>	<del>SDR-26</del>	<del>-</del>
<del>* SAS #100</del>	<del>SAS #101</del>	<del>1044.54</del>	<del>1049.40</del>	<del>325</del>	<del>1.50%</del>	<del>10"</del>	<del>SDR-26</del>	<del>-</del>
<del>* SAS #101</del>	<del>SAS #102</del>	<del>1049.50</del>	<del>1054.78</del>	<del>352</del>	<del>1.50%</del>	<del>10"</del>	<del>SDR-26</del>	<del>-</del>
<del>* SAS #102</del>	<del>SAS #103</del>	<del>1054.88</del>	<del>1061.19</del>	<del>210</del>	<del>3.00%</del>	<del>10"</del>	<del>SDR-26</del>	<del>-</del>
<del>* SAS #103</del>	<del>SAS #104</del>	<del>1061.29</del>	<del>1067.65</del>	<del>212</del>	<del>3.00%</del>	<del>10"</del>	<del>SDR-26</del>	<del>-</del>

## SPECIFIC NOTES

- [1] CASTING SHALL BE SAS LOCKING FRAME & LOGO COVER PER S.D.D. 5.7.16A. NO ADJUSTMENT RINGS SHALL BE USED
- [2] INSTALL INTERNAL CHIMNEY SEAL IN ACCORDANCE WITH S.D.D. 5.7.17
- \* [3] INSTALL EXTERNAL SEWER ACCESS STRUCTURE JOINT SEAL
- \* [4] INSTALL EXTERNAL SEWER ACCESS STRUCTURE JOINT SEAL TO EXISTING STRUCTURE