



Department of Public Works
Engineering Division
James M. Wolfe, P.E., City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineerin

Assistant City Engineer

Bryan Cooper, AIA
Gregory T. Fries, P.E.
Chris Petykowski, P.E.

Principal Architect

Amy Loewenstein Scanlon, AIA

Principal Engineer 2

Janet Schmidt, P.E.

Principal Engineer 1

Kyle Frank, P.E.
Mark D. Moder, P.E.
Fadi El Musa Gonzalez, P.E.
Andrew J. Zwieg, P.E.

Financial Manager

Steven B. Danner-Rivers

July 7, 2026

ADDENDUM NO. 01

**MADISON MUNICIPAL BUILDING FLAGPOLE REPLACEMENT
CITY OF MADISON – CONTRACT 9805**

This addendum is issued to modify, explain or correct the original Drawings, Specifications, or Contract Documents marked as ***Madison Municipal Building Flagpole Replacement, City of Madison, Contract #9805, as issued on June 25, 2026***, and is hereby made a part of the contract documents.

Please attach these Addendum documents to the Construction Drawings (Exhibit A), Project Manual (Exhibit B), and Bid Proposal Contract Bond and Specifications document in your possession.

1. BID PROPOSAL, CONTRACT, BOND AND SPECIFICATIONS DOCUMENT

No revisions.

2. ACCEPTABLE SUBSTITUTIONS

No accepted substitutions.

3. PROJECT MANUAL SPECIFICATIONS

No change to specifications.

4. CONSTRUCTION DRAWINGS

No change to construction drawings.

5. GENERAL QUESTIONS

Question 1: What landscape should be included?

Answer 1: Torpedo wash sand shall be used to fill the planters per detail 2/S2. City staff will install plants in the planters once the work is complete. Grass seed as specified in [Standard Specification Article 207.2\(a\)](#) shall be used for any lawn repairs.

Question 2: Please confirm the height/length of the flagpole.

Answer 2: The flagpole is 70' long. A portion of the 70' height will be buried below grade.

Question 3: Please share the sign in sheet from the site tour.

Answer 3: Attached.



**MADISON MUNICIPAL BUILDING FLAGPOLE REPLACEMENT
CITY OF MADISON – CONTRACT 9805**

Please acknowledge this addendum on pages A1, S0, S2, and E0 of the Bid Proposal Contract Bond and Specifications document and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on Bid Express at <https://www.bidexpress.com/> and the City of Madison web site at <http://www.cityofmadison.com/business/PW/contracts/openforBid.cfm>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 to receive the material by another method.

For questions regarding this bid, contact:

Steve White
City of Madison Engineering
Phone: 608-266-5969
Email: swhite@cityofmadison.com

Bryan Cooper

Bryan Cooper, Deputy City Engineer, AIA

END OF ADDENDUM

Pre-Bid Tour Date:

[illegible]