



NOTE: RESTRAIN ENTIRE LENGTH OF HYDRANT LEAD FROM THE TEE THROUGH THE VALVE TO THE HYDRANT AS SPECIFIED USING MECHANICAL JOINT REDRAINTS.

POURED CONCRETE THRUST BLOCK TO UNDISTURBED SOIL

2004

CITY OF MADISON WATER UTILITY
TYPICAL HYDRANT INSTALLATION
STANDARD DETAIL DRAWING 7.04