

The City of Madison Fire Department's

# Guide to Grilling!

What kind of grill do you have?



What size is the LP container?

LESS than 2½ lbs.

Use:

CANNOT be used within 10' of combustible construction

Exceptions:  
♦ Balconies with sprinklers  
♦ 1&2-family homes

MORE than 2½ lbs.

Use:

CANNOT be used within 10' of combustible construction

Exceptions:  
♦ Balconies with sprinklers AND exterior stairs  
♦ 1&2-family homes

NOTE:  
LP containers larger than 2½ lbs. cannot be stored or transported through building

Storage:

CANNOT be stored on decks or balconies above 1st floor

Exceptions:  
♦ Balconies with exterior stairs  
♦ 1&2-family homes

NOTE:  
MUST be at least 5' away from building openings (e.g., doors & windows)



Use:

Natural gas MUST be hard-piped AND follow the Fuel Gas Code requirements

CANNOT be used within 10' of combustible construction

Exceptions:  
♦ Balconies with sprinklers  
♦ 1&2-family homes



(also pellet or other open-flame grills)

Use:

CANNOT be used within 10' of combustible construction

Exceptions:  
♦ Balconies with sprinklers  
♦ 1&2-family homes



Use:

OK to use on any balcony



Grill Safely!

