

# PRIVATE HYDRANTS ANNUAL TESTING AND MAINTENANCE



Owner's Name: \_\_\_\_\_  
 Building Address: \_\_\_\_\_  
 Owner's Phone #: \_\_\_\_\_ Emergency Contact #: \_\_\_\_\_  
 Person Doing Inspection: \_\_\_\_\_

Name of company servicing hydrant: \_\_\_\_\_ Phone #: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 Signature of tech: \_\_\_\_\_ Print name: \_\_\_\_\_ Date of service: \_\_\_\_\_  
 # of hydrants serviced: \_\_\_\_\_ Make/model of hydrants: \_\_\_\_\_

Y = Satisfactory    N = Unsatisfactory (explain below)    N/A = Not Applicable

<b>Annual Maintenance</b>	<b>INSPECTION YEAR:</b>
Lubricate operating nut	
Lubricate hydrant packing	
Lubricate thrust collar	
Lubricate outlet threads	

<b>Annual Testing</b>	
Open hydrant fully and flow for <b>not less</b> than 1 minute	
Hydrant shall drain completely within 60 minutes of closing valve	
Note: Contact the Water Utility Dept at 266-4665 <b>prior</b> to flowing hydrants	

This form covers a 1-year period

Notes:

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

Completed forms shall be submitted to:  
 Hydrant Records, Madison Fire Department  
 314 W. Dayton St.  
 Madison, WI 53703



This form, or another approved form (such as an NFPA form) must be completed in a timely manner and be readily available for inspection. This form may be freely reproduced or copied and used without charge. The Madison Fire Department does not make any claims as to the usability of this form for inspection purposes outside the City of Madison. Please visit our website at <http://www.madisonfire.org>