



Fireplace

MGO 34.307

- (a) Fireplaces shall include a bowl with supports to ensure clearances to combustibles;
- (b) Pits shall have an enclosure, heavy screen or spark arrestor to control and contain embers and sparks;
- (c) Fireplaces or pits shall not be used within fifteen (15) feet of a building or lot line;
- (d) Fireplaces or pits shall be used on a stable level surface;
- (e) Fireplaces or pits shall not be used on any combustible deck, porch or patio;
- (f) Only clean, dry wood is permitted to be burned in fireplaces or pits. No trash, yard waste or construction material shall be burned;
- (g) If the fireplace is a propane unit, only propane shall be burned;
- (h) The smoke from a fireplace or pit shall not create a nuisance.

If those conditions are met, you do not need a burn permit from MFD.