



Department of Planning & Community & Economic Development
Planning Division

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266-4747
FAX 608 266-8739
PH 608 266-4635

October 7, 2009

J. Randy Bruce
Knothe & Bruce Architects, LLC
7601 University Avenue, Suite 201
Middleton, Wisconsin 53562

RE: Approval of a request a major alteration to an approved Planned Unit Development General Development Plan/ Specific Implementation Plan to allow construction of a 30-unit apartment building in place of a previously approved office building at 1 Hawks Landing Circle. (Jeff Haen, JAKS Investments)

Dear Mr. Bruce;

At its October 6, 2009 meeting, the Common Council **conditionally approved** your client's application for a major alteration to an approved PUD-GDP-SIP to allow construction of a 30-unit apartment building at 1 Hawks Landing Circle. The following conditions of approval shall be satisfied prior to final approval and recording of the planned unit development and the issuance of permits for construction:

Please contact Janet Dailey, City Engineering Division, at 261-9688 if you have questions regarding the following eight items:

1. Upper Badger Mill Creek impact fees are due and payable unless paid previously.
2. Submit a PDF of all floor plans to Lori Zenchenko, lzenchenko@cityofmadison.com, so that a preliminary interior addressing plan can be developed. If there are any changes pertaining to the location of a unit, the deletion or addition of a unit, or to the location of the entrance into any unit, (before, during, or after construction) the addresses may need to be changed. The interior address plan is subject to the review and approval of the Fire Marshal.
3. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
4. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to: provide infiltration in accordance with Chapter 37 of the Madison General Ordinances; provide substantial thermal control; provide oil & grease control from the first 1/2" of runoff from parking areas, and; complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website as required by Chapter 37 of the Madison General Ordinances.

5. The applicant shall submit, prior to plan sign-off, digital CAD files to the Land Records Coordinator in the Engineering Division. (Lori Zenchenko) lzenchenko@cityofmadison.com. The digital copies shall be drawn to scale and represent final construction including: building footprints, internal walkway areas, internal site parking areas, lot lines/ numbers/ dimensions, street names, and other miscellaneous impervious areas. All other levels (contours, elevations, etc) are not to be included with this file submittal. Email file transmissions are preferred. The digital CAD file shall be to scale and represent final construction. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format. Please include the site address in this transmittal.
6. The applicant shall submit, prior to plan sign-off, digital PDF files to the City Engineering Division. The digital copies shall be to scale, shall have a scale bar on the plan set, and shall contain the following items: building footprints; internal walkway areas; internal site parking areas; lot lines and right-of-way lines; street names, stormwater management facilities and; detail drawings associated with stormwater management facilities (including if applicable planting plans).
7. The applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management File including: SLAMM DAT files; RECARGA files; TR-55/HYDROCAD/etc., and; sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.
8. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.

Please contact John Leach, Traffic Engineering Division, at 267-8755 if you have questions about the following item:

9. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), adjacent driveway approaches to lots on either side and across the street, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the 2-foot overhang, and a scaled drawing at 1" = 20'.

Please contact Pat Anderson, Assistant Zoning Administrator, at 266-5978 if you have any questions regarding the following six items:

10. Parking requirements for persons with disabilities must comply with Section 28.11 (3)6.(m), MGO, which includes all applicable State accessible requirements.
11. Bike parking shall comply with MGO Section 28.11: Provide one bike parking stall for each apartment (30 additional) in a safe and convenient locations on an impervious surface to be shown on the final plan. The bike racks shall be securely anchored to the ground or building to prevent the racks from moving. Note: A bike-parking stall is 2' by 6' with a 5-foot access area.
12. Off-street parking requirement shall comply with MGO Section 28.11: Parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note:

The required trees do not count toward the landscape point total.) Call out on final plans surface parking devoted to Bldg "A".

13. Lighting is required and shall be in accordance with MGO Section 10.085: Provide a plan showing at least .5 foot candle on any surface on any lot and an average of .75 footcandles. The maximum light trespass shall be 0.5 footcandle at 10 feet from the adjacent lot line. (See City of Madison Lighting Ordinance).
14. The zoning text under "A" permitted uses shall include "accessory uses to the permitted uses above." The text under "B" shall state "Planned Unit Development" instead of "Planned Community Development".
15. Signage must be approved by the Urban Design Commission or staff. Sign permits must be issued by the Zoning Section of the Department of Planning and Community and Economic Development prior to sign installations.

Please contact Scott Strassburg, Madison Fire Department, at 261-9843 if you have any questions regarding the following item:

16. Provide fire apparatus access as required by Comm. 62.0509 and MGO 34.19, as follows: The site plans shall clearly identify the location of all fire lanes.

Please contact Tom Maglio, Parks Division, at 266-4711 if you have questions about the following item:

17. The developer shall pay \$59,791.50 for park dedication and development fees for the additional 30 multi-family units. The developer must select a method for payment of park fees before signoff on the rezoning. The park fees shall be paid prior the issuance of building permits.

Park Dedication required for the multi-family units = 30 units at 700 square feet per unit = 21,000 square feet. The Fee in Lieu of Dedication is based on current property values up to \$2.01 per square foot for 2009 = \$42,210.00. Park development fees = 30 units at \$586.05 = \$17,581.50 = \$59,791.50.

Please contact my office at 261-9632 if you have questions about the following two items:

18. That the applicant work with the Planning Division and Zoning Administrator prior to final approval and recording of the planned unit development to develop an enumerated list of permitted commercial and office uses for the zoning text. [Staff believes that it would be best going forward to approve PUD zoning texts with such use lists so as to avoid references to the existing Zoning Code, which is currently being rewritten and will likely have different, more contemporary use lists.]
19. The revised zoning text shall also specifically identify "Multi-family residential uses as shown on approved plans" as a permitted use.

The applicant is also required to satisfy the conditions of approval of the Urban Design Commission prior to the final staff approval of the project and the issuance of building permits. Please contact Al Martin, Urban Design Commission Secretary, at 267-8740 if you have any questions about those conditions.

After the plans have been changed as per the above conditions, please file **ten (10) sets** of the revised, complete site plans, building elevations, floor plans and any other documentation requested herein with

the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their signature of final approval.

Upon receipt of the aforementioned plans, documents and fees, and upon determining that they are complete, the Zoning Administrator shall record them with the Dane County Register of Deeds Office. The recorded originals will be returned to the applicant, with the recording information noted, when the Register of Deeds has completed the recording process.

If this plan is not recorded within one year of the date of approval by the Common Council, the approval shall be null and void. No construction or alteration of the property included in this application shall be permitted until a Specific Implementation Plan (SIP) has been approved and recorded.

Within thirty-six (36) months of Common Council approval of the general development plan, the basic right of use for the areas, when in conformity with the approved specific implementation plan, shall lapse and be null and void unless 1) the project, as approved, is commenced by the issuance of a building permit, or 2) if an application for an extension is filed at least thirty (30) days prior to the expiration of the thirty-six (36) month period and the Plan Commission, after a public hearing pursuant to Sec. 28.12 (10)(e), determines that no changes in the surrounding area or neighborhood since approval of the general development plan render the project incompatible with current conditions and grants an extension of up to twenty-four (24) months in which to obtain a building permit. In no case shall an extension allow a building permit to be issued more than sixty (60) months after approval of the general development plan by the Common Council. If a new building permit is required pursuant to sec. 29.06(4), Madison General Ordinances, a new petition and approval process shall be required to obtain general development plan approval and specific implementation plan approval.

If you have any questions regarding recording this plan or obtaining permits, please call Matt Tucker, Zoning Administrator, at 266-4551. If I may be of any further assistance, please do not hesitate to contact me at 261-9632.

Sincerely,

Timothy M. Parks
Planner

cc: Janet Dailey, City Engineering Division
John Leach, Traffic Engineering Division
Tom Maglio, Parks Division
Scott Strassburg, Madison Fire Department
Pat Anderson, Asst. Zoning Administrator

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (T. Parks)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other: