



Department of Planning & Development  
**Planning Unit**

Website: [www.cityofmadison.com](http://www.cityofmadison.com)

Madison Municipal Building  
215 Martin Luther King, Jr. Boulevard  
P.O. Box 2985  
Madison, Wisconsin 53701-2985  
TDD 608 266-4747  
FAX 608 266-8739  
PH 608 266-4635

June 21, 2006

J. Randy Bruce  
Knothe & Bruce Architects, LLC  
7601 University Avenue, Suite 201  
Middleton, Wisconsin 53562

RE: Approval of a request to rezone 625-627 E. Mifflin Street from C3 (Highway Commercial District) to Planned Unit Development, General Development Plan/ Specific Implementation Plan (PUD-GDP-SIP) to allow demolition of an existing auto-repair garage and the construction of a 66-unit condominium building.

Dear Mr. Bruce:

At its June 20, 2006 meeting, the Common Council **conditionally approved** your client's application to rezone property located at 625-627 E. Mifflin Street from C3 to PUD-GDP-SIP. The following conditions of approval shall be satisfied prior to final approval and recording:

**Please contact Janet Gebert, City Engineering, at 266-4751 if you have questions regarding the following eighteen (18) items:**

1. Provide details of proposed retaining wall with design certified by a professional engineer. If the retaining wall system encroaches onto neighboring properties, provide proof of an easement.
2. Prior to approval, owner shall execute a maintenance agreement for retaining walls and storm water management components.
3. Revise sanitary lateral connection to City main to existing manhole SAS 5247-036 located in East Mifflin Street approximately 30-feet away from the east property line of the development.
4. The construction of this building will require removal and replacement of sidewalk, curb and gutter and possibly other parts of the City's infrastructure. The applicant shall enter into a City/Developer agreement for the improvements required for this development. The applicant shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The applicant shall meet with the City Engineer to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. The developer shall sign the Developer's Acknowledgement prior to the City Engineer signing off on this project.
5. The applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
6. The approval of this project does not include the approval of the changes to roadways, sidewalks or utilities. The applicant shall obtain separate approval by the Board of Public Works and the Common Council for the

restoration of the public right of way including any changes requested by developer. The City Engineer shall complete the final plans for the restoration with input from the developer. The curb location, grades, tree locations, tree species, lighting modifications and other items required to facilitate the development or restore the right of way shall be reviewed by the City Engineer, City Traffic Engineer, and City Forester.

7. The applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The applicant shall hire a professional engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development.
8. The Applicant shall replace all sidewalk and curb and gutter which abuts the property that is damaged by the construction or any sidewalk and curb and gutter that the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
9. A City licensed contractor shall perform all work in the public right-of-way.
10. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
11. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to provide oil & grease control from the first 1/2" of runoff from parking areas.
12. The Applicant shall submit, prior to plan sign-off, digital CAD files to the Land Records Coordinator in the Engineering Division (Lori Zenchenko). The digital copies shall be drawn to scale and represent final construction, including: building footprints, internal walkway areas, internal site parking areas, and other miscellaneous impervious areas.
13. The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, shall have a scale bar on the plan set, and shall contain the following items: building footprints; internal walkway areas; internal site parking areas; lot lines and right-of-way lines; street names, stormwater management facilities and; detail drawings associated with stormwater management facilities (including if applicable planting plans).
14. The applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit.
15. The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work.
16. The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction.
17. Prior to approval of the project, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1) \$100 non-refundable

deposit for the cost of inspection of the plugging by City staff; and (2) \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner.

18. All outstanding Madison Metropolitan Sewerage District (MMSD) and City of Madison sanitary sewer connection charges are due and payable prior to connection to the public sewerage system.

**Please contact John Leach, Traffic Engineering, at 267-8755 if you have questions about the following seven items:**

19. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be review by Traffic Engineer to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds four stories prior to sign-off to be reviewed and approved by Keith Lippert, (266-4767) Traffic Engineering Shop, 1120 Sayle Street. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.
20. When the applicant submits final plans for approval, the plans shall show the following: items in the terrace as existing (signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, on a scaled drawing at 1" = 20'.
21. The ramp down to underground parking percent of sloped shall be designed to accommodate low-clearance vehicles for a transition. Ramp breakover angle (limited by vehicle wheel-base and ground clearance) and angles of approach (affected by front overhang of vehicles) and departure (affected by rear overhang) are critical vehicle clearance points. Standards established by the Society of Automotive Engineers limit the ramp breakover angle to no less than 10 degrees; angle of departure, no less than 10 degrees; and angle of approach, no less than 15 degrees. The applicant shall provide a profile of the ramp showing the slopes critical clearance, when plans are submitted for approval. The applicant should explore ramp slopes (grades) less than 8% that can be blended satisfactorily with an 8-foot transition length.
22. The applicant shall note the truck loading area on the First Floor Plan to underground parking. The area shall be dimensions for proposed the enclosed bike racks and turning area into the garage. The applicant shall demonstrate a vehicle turning into the first floor area.
23. All signs at the approaches shall be installed behind the property line. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
24. The developer shall post a deposit and reimburse the City for all costs associated with any modifications to traffic signals, street lighting, signing and pavement marking, and conduit and handholes, including labor, engineering and materials for both temporary and permanent installations.
25. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

**Please contact Si Widstrand, Parks Division, at 266-4711 if you have questions about the following item:**

26. Park dedication required for this project is 46,200 square feet based on 700 square feet per unit for the 66 units. The required dedication shall be paid as a fee in lieu of land, based on the actual value of the acreage up to a maximum of \$1.74 per square foot. The dedication fee for this project is \$80,388.00. Park Development

Fees are \$34,594.56 (\$524.16 per unit). → Total park fees for this project = **\$114,982.56**. Park fees shall be paid prior to each SIP signoff.

**Please contact John Lippitt, Madison Fire Department, at 261-9658 if you have questions about the following two items:**

27. If the building is fully sprinklered, the Madison Fire Department will accept up to 250 feet of hose reach.
28. Provide fire apparatus access as required by Comm. 62.0509 and MGO 34.19 as follows:
  - a.) the site plans shall clearly identify the location of all fire lanes;
  - b.) provide a completed MFD "Fire Apparatus Access and Fire Hydrant Worksheet" with the site plan submittal.

**Please contact Kathy Voeck, the Assistant Zoning Administrator, at 266-4551 if you have questions regarding the following four items:**

29. Section 28.04(25) provides that Inclusionary Zoning requirements shall be complied with as part of the approval process. Submit, to CDBG, a copy of the approved plan for recording prior to zoning sign off of the plans.
30. Show building setbacks on the site plan. Show cantilevered portions of the building on the site plan.
31. Show the height of the building per City Datum. No portion of any building or structure located within one mile of the center of the State Capitol Building shall exceed the elevation of the base of the columns of the Capitol Building or one hundred eighty-seven and two-tenths (187.2) feet, City datum. Except this prohibition shall not apply to elevator penthouses, and chimneys exceeding such elevation, when approved as a conditional use. For the purpose of this subsection, City datum zero (0.00) feet shall be established as eight hundred forty-five and six-tenths (845.6) feet above sea level as established by the United States Coast and Geodetic Survey.
32. Meet all applicable State accessible requirements, including but not limited to:
  - a.) Provide a minimum of **two** accessible stalls and striped per State requirements. A minimum of one of the stalls shall be a van accessible stall 8' wide with an 8' striped out area adjacent.
  - b.) Show signage at the head of the stalls. Accessible signs shall be a minimum of 60" between the bottom of the sign and the ground/floor.
  - c.) Show the accessible path from the stalls to the building or elevator in the garage. The stalls shall be as close to the accessible entrances as possible.

**Please contact my office at 261-9632 if you have questions about the following item:**

33. That the applicants submit a final Inclusionary Dwelling Unit Plan for approval and recording as part of the PUD-GDP-SIP for the project that includes a complete IDUP, marketing plan and Land Use Restriction Agreement (LURA).

A reuse and recycling plan approved by the Recycling Coordinator is required by ordinance prior to the recording of the PUD and issuance of a wrecking permit.

Approval of this project does not include any approval to prune, remove or plant trees in the public right of way. Permission for such activities must be obtained from the City Forester, 266-4816.

After the plans have been changed as per the above conditions, please file **ten (10) sets** of the revised, complete site plans, building elevations, floor plans and any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their signature of final approval.

Upon receipt of the aforementioned plans, documents and fees, and upon determining that they are complete, the Zoning Administrator shall record them with the Dane County Register of Deeds Office. The recorded originals will be returned to the applicant, with the recording information noted, when the Register of Deeds has completed the recording process.

If this plan is not recorded within one year of the date of approval by the Common Council, the approval shall be null and void. No construction or alteration of the property included in this application shall be permitted until a Specific Implementation Plan (SIP) has been approved and recorded.

Within thirty-six (36) months of Common Council approval of the general development plan, the basic right of use for the areas, when in conformity with the approved specific implementation plan, shall lapse and be null and void unless 1) the project, as approved, is commenced by the issuance of a building permit, or 2) if an application for an extension is filed at least thirty (30) days prior to the expiration of the thirty-six (36) month period and the Plan Commission, after a public hearing pursuant to Sec. 28.12(10)(e), determines that no changes in the surrounding area or neighborhood since approval of the general development plan render the project incompatible with current conditions and grants an extension of up to twenty-four (24) months in which to obtain a building permit. In no case shall an extension allow a building permit to be issued more than sixty (60) months after approval of the general development plan by the Common Council. If a new building permit is required pursuant to sec. 29.06(4), Madison General Ordinances, a new petition and approval process shall be required to obtain general development plan approval and specific implementation plan approval.

If you have any questions regarding recording this plan or obtaining permits, please call Matt Tucker, Zoning Administrator, at 266-4551. If I may be of any further assistance, please do not hesitate to contact me at 261-9632.

Sincerely,

Timothy M. Parks  
Planner

cc: Kathy Voeck, Asst. Zoning Administrator  
Janet Gebert, City Engineering  
Si Widstrand, Parks Division  
John Leach, Traffic Engineering  
John Lippitt, Madison Fire Department

For Official Use Only, Re: Final Plan Routing/ Reuse-Recycling Routing			
<input checked="" type="checkbox"/>	Planning Unit (T. Parks)	<input type="checkbox"/>	Madison Water Utility
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division (park fees only)
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coordinator (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Metro Transit
<input checked="" type="checkbox"/>	CDBG Office	<input type="checkbox"/>	Other: