



Department of Planning & Development  
**Planning Unit**

Website: [www.cityofmadison.com](http://www.cityofmadison.com)

Madison Municipal Building  
215 Martin Luther King, Jr. Boulevard  
P.O. Box 2985  
Madison, Wisconsin 53701-2985  
TDD 608 266-4747  
FAX 608 266-8739  
PH 608 266-4635

November 8, 2006

Mike Marty  
Calkins Engineering, LLC  
5010 Voges Road  
Madison, Wisconsin 53718

RE: Approval of a final plat of "Replat of Lots 36-48, Pine Hill Farm" creating nine single-family lots from twelve previously platted lots in the Pine Hill Farm subdivision. (Bill Holley).

Dear Mr. Marty:

At its November 7, 2006 meeting, the Common Council **approved** your client's final plat for the "Replat of Lots 36-48, Pine Hill Farm" subdivision subject to the following conditions of approval from reviewing agencies:

**Please contact Janet Dailey, City Engineering, at 261-9688 if you have questions regarding the following eighteen (18) items:**

1. The existing 55-foot wide Open Space Easement is also a 55-foot wide Perpetual Easement for Public Storm Water Management Purposes per Document No. 4213494. Revise plat to include this documentation.
2. Applicant shall confirm that the location of sanitary laterals will work with new lot configuration. Prior to approval, submit as built plan of existing laterals and those proposed to be used or abandoned.
3. Prior to approval, provide evidence of recorded assessment waiver for proposed Lower Badger Mill Creek Storm and Sanitary Impact Fees.
4. The developer shall enter into a City/ Developer agreement for the installation of public improvements required to serve this plat. The developer shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The developer shall meet with the City Engineer to schedule preparation of the plans and the agreement. The City Engineer will not sign off on this plat without the agreement executed by the developer.
5. The developer shall construct Madison standard street improvements for all streets within the plat.

6. An erosion control plan and land disturbing activity permit shall be submitted to the Engineering Division for review and approval prior to grading or any other construction activities. The Preconstruction Meeting for Public Improvements shall not be scheduled prior to issuance of this permit. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
7. The following notes shall be included on the final plat:
  - a.) All lots within this plat are subject to public easements for drainage purposes which shall be a minimum of 6 feet in width measured from the property line to the interior of each lot except that the easements shall be 12 feet in width on the perimeter of the plat. For purposes of two (2) or more lots combined for a single development site, or where two (2) or more lots have a shared driveway agreement, the public easement for drainage purposes shall be a minimum of six (6) feet in width and shall be measured only from the exterior property lines of the combined lots that create a single development site, or have a shared driveway agreement, except that the easement shall be twelve (12) feet in width along the perimeter of the plat. Easements shall not be required on property lines shared with greenways or public streets. No buildings, driveways, or retaining walls shall be placed in any easement for drainage purposes. Fences may be placed in the easement only if they do not impede the anticipated flow of water.

Note: In the event of a City Of Madison Plan Commission and/or Common Council approved re-division of a previously subdivided property, the underlying public easements for drainage purposes are released and replaced by those required and created by the current approved subdivision.
  - b.) The intra-block drainage easements shall be graded with the construction of each principle structure in accordance with the approved storm water drainage plan on file with the City Engineer and the Zoning Administrator, as amended in accordance with the Madison General Ordinances.
8. Prior to the issuance of building permits, the developer shall submit a master stormwater drainage plan to the City Engineering Division for review and approval which shows lot corner elevations to the nearest 0.25-foot. For purposes of the plan, it shall be assumed that grading shall be done on a straight-line grade between points unless other information is provided. The proposed slope between points shall always be greater than or equal to .0075 ft/ft. If a break in grade is required between lot corners a shot shall be taken at that break in grade to provide the Engineer with enough information to interpret the plan. The developer shall also show proposed drainage arrows on the plan to indicate the proposed direction of drainage.

The master storm water drainage plan shall be submitted to City Engineering in digital format with elevations/grades/contours shown on the recorded plat map of the development. The digital record shall be provided using the state plane coordinate system – NAD 27.

The following note shall accompany the master storm water drainage plan:

*“For purposes of this plan, it is assumed that grading shall be a straight line grade between points unless otherwise indicated. All slopes shall be 0.75% or steeper. Grade breaks between lot corners are shown by elevation or through the use of drainage arrows. ”*

No building permits shall be issued prior to City Engineering’s approval of this plan.

9. A minimum of two (2) working days prior to requesting City Engineering signoff on the plat, the applicant shall contact Janet Dailey (608-261-9688) to obtain the final stormwater utility charges that are due and payable prior to sub-division of the properties. The stormwater utility charges (as all utility charges) are due for the previous months of service. All charges shall be cleared prior to the land division (and subsequent obsolesces of the existing parcel).
10. Wisconsin Administrative Code A-E 7.08 identifies when Public Land System (PLS) tie sheets must be filed with the Dane County Surveyor’s office. The Developer’s Surveyor and/or Applicant must submit copies of required tie sheets or condition reports for all monuments, including center of sections of record, used in this survey, to Eric Pederson, City Engineering. If a new tie sheet is not required under A-E 7.08, Engineering requests a copy of the latest tie sheet on record with Dane County Surveyor’s office. The Applicant shall identify monument types on all PLS corners included on the Plat or CSM. Note: Land tie to two PLS corners required.
11. In accordance with Section s. 236.18(8), Wisconsin Statutes, the Applicant shall reference City of Madison NAD 1927 Coordinates on all PLS corners on the Plat or Certified Survey Map in areas where this control exists. The Surveyor shall identify any deviation from City Master Control with recorded and measured designations. City of Madison has established NAD 1927 Coordinates on all PLS corners within its corporate boundary. Visit the City of Madison Engineering Division web address site for current tie sheets and control data. If a surveyor encounters an area without a published NAD 1927 value, contact Engineering Division for this information.
12. In accordance with Section s.236.34(1) (c) which says a plat shall be prepared in accordance with s.236.20(2) (c) & (f), Wisconsin Statutes, the Applicant must show type, location and width of any and all easements. Clearly identify the difference between existing easements (site Register of Deeds recording data) and easements that are being conveyed by the plat. Identify the owner and/or benefiting interest of all easements.
13. The Applicant shall submit to Eric Pederson, prior to Engineering sign-off of the subject plat, two (2) digital and one (1) hard copy of the final plat to the Mapping/GIS Section of the Engineering Division. The digital copies shall be submitted in both NAD27 & WIDOT County Coordinate System, Dane County Zone datums and be consistent with previous formats delivered to the City by the Applicant and contain the minimum of the following, each on a separate layer name/level number: right of way lines (public and private); lot lines; lot numbers; lot/plat dimensions; street names, and; easement lines (i.e. street, sanitary, storm (including wetland & floodplain boundaries) water, pedestrian/bike/walkway, or any public and/or private interest easement except **local service** for Cable TV, gas, electric and fiber optics).

\*This transmittal is a separate requirement than the required submittals to Bob Arseneau for design purposes.

Replat of Lots 36-48,  
Pine Hill Farm  
November 8, 2006  
Page 4

\*New electronic final plat transmittals and notification of changes which occur to the final plat during the time the Engineering Division signs off and receives the digital copies of said plat and the recording thereof, are the responsibility of the Developer/Surveyor.

**Please contact John Leach, Traffic Engineering, at 267-8755 if you have questions about the following item:**

14. The applicant shall execute and return the attached declaration of conditions and covenants for streetlights and traffic signals prior to sign off.

**Please note that the City Real Estate Office is reviewing the report of title provided with this plat and may have comments. That office will send any comments to you by fax. If you have any questions, please contact Jeff Ekola at 267-8719 for more information.**

Specific questions regarding comments or conditions should be directed to the commenting agency. Any appeal regarding the plat, including the conditions of approval, must be filed with the Circuit Court within thirty (30) days from the date of this letter. If I may be of any further assistance, do not hesitate to contact me at 261-9632.

Sincerely,

Timothy M. Parks  
Planner

cc: Janet Dailey, City Engineering  
John Leach, Traffic Engineering  
Kathy Voeck, Assistant Zoning Administrator  
Jeff Ekola, Real Estate Unit  
Norb Scribner, Dane County Land Records and Regulations