

**PLANNING DIVISION REPORT
DEPARTMENT OF PLANNING AND COMMUNITY
AND ECONOMIC DEVELOPMENT
September 15, 2008**

RE: LD. #11931, Demolition Permit and Conditional Use – 344 S. Yellowstone Drive

1. Requested Action: Approval of a demolition permit for an office building to construct a dental office building.
2. Applicable Regulations: Section 28.04 (22) provides the guidelines and regulations for the approval of demolition permits. The property includes a deed restriction, recorded in 1989, stating “alterations to the exterior of the building that would materially change the height or floor area of the building shall not be permitted except after review and approval as a conditional use by the Plan Commission.” Section 28.12 (11) provides the guidelines and regulations for the approval of conditional uses.
3. Report Drafted By: Kevin Firchow, AICP, Planner

GENERAL INFORMATION:

1. Applicant & Agent: John Bieno; TJK Design Build 634 West Main Street; Madison, WI 53703
Property Owner: Kevin Carey; The Carey Group; 2801 Coho Street, Suite 101; Madison, WI 53713
2. Development Schedule: The project will commence on October 1, 2008 with completion anticipated by February 1, 2009.
3. Parcel Location: A 20,658 square foot parcel located at the northwest corner of Mineral Point Road and Yellowstone Drive; Aldermanic District 19, Madison Metropolitan School District.
4. Existing Conditions: The site includes a one-story, 3,500 square foot office building.
5. Proposed Use: The applicant proposes a one-story, 4,450 square foot dental office building.
6. Surrounding Land Use and Zoning:
North and West: 32-unit apartment building, zoned R4 (General Residence District),
East: 99-unit condominium development, zoned R4 (General Residence District), and
South: Office building, zoned C3L (Commercial Service and Distribution District).

7. **Adopted Land Use Plan:** The subject site is recommended for Medium-Density Residential uses (MDR) in the City of Madison Comprehensive Plan. This recommendation states that limited amount of office and service uses could be located within medium-density residential areas.
8. **Environmental Corridor Status:** This property is not located within a mapped environmental corridor.
9. **Public Utilities and Services:** This property is served by a full range of urban services.

STANDARDS FOR REVIEW:

This application is subject to the conditional use standards of Section 28.12 (11) and the demolition standards of Section 28.04 (22).

ANALYSIS, EVALUATION AND CONCLUSION:

The applicant requests approval to demolish an existing one-story office building to allow for the construction of a new dental office building. The property includes a deed restriction, recorded in 1989, stating "alterations to the exterior of the building that would materially change the height or floor area of the building shall not be permitted except after review and approval as a conditional use by the Plan Commission." Therefore, this application is subject to the conditional use standards of Section 28.12 (11) and the demolition standards of Section 28.04 (22).

The existing one-story building was constructed in 1972 as the Parkwood Hills Preschool. The City's Preservation Planner believes it is of no known architectural interest or historical significance. This 3,500 square foot structure is sited roughly at the center of the property, with a small portion of the building close to the Mineral Point frontage. Parking is currently located west of the building.

Pictures of the existing building have been provided. Staff have not conducted a formal inspection of the interior and have no information indicating that this building is not structurally sound. The applicant notes that remodeling this facility was considered, however, it was determined to be more cost effective to pursue demolition and construct a new structure versus retrofitting the current building to suit dental office purposes. The applicant notes space conflicts with an existing crawl space, the need for additional floor joists, and overall serviceability concerns as deficiencies with the existing building.

The proposed building is a slightly larger 4,450 one-story dental office building. The new building would have an increased street presence, with additional building frontage provided approximately 13 feet from the Mineral Point Road right-of-way. The main entrance is located on the opposite, parking lot-facing side of the building. In preliminary meetings with the applicant, staff noted its preference to have a street-oriented entrance. The applicant has responded by providing a pedestrian walk from the main entrance to the public sidewalk along

the building's west side. Changes in site grade require that this walk include stairs. A direct, accessible route is located along Yellowstone Drive.

The site includes 25 parking stalls, located on the north and west sides of the building. The parking fronting on Mineral Point Road would be partially screened by new vegetation and boulder retaining wall.

The existing office is somewhat residential in character, and includes materials, rooflines, and window openings resembling that of a "suburban" single-family home. This generally blends in with the adjacent residential structures. The proposed structure is less residential in character. The proposed features a four-sided design, consisting of ground level split-faced block, a brick body, and EIFS along the top of the building. Colors include a light-cream colored base, an orange/copper colored brick, and tan EIFS band. The applicant has provided revised elevations that now include roof-top photovoltaic solar panels on the Mineral Point Road elevation. The remainder of the roof includes a simulated shake asphalt shingle. While not as residential in character, staff believe the proposed structure would be complementary to surrounding buildings. Staff requests the applicant revises the Yellowstone Drive elevation to improve its street presence. It is recommended that the applicant utilize larger windows that extend closer to the ground or provide other design treatments to address this concern.

The applicant has updated the original landscape plan. The new plan provides increased screening and foundation plantings along the Mineral Point frontage including lilac and hydrangea. The east side of the building includes a landscaped perimeter bed featuring evergreen yews. As the property is adjacent to a residentially zoned property, six to eight-foot tall screening would be required as noted in the Assistant Zoning Administrator's comments.

The Comprehensive Plan recommends medium density residential uses for this site. Neighborhood serving business and office, such as the proposed, are included within this broad recommendation and therefore, staff believe this proposal to be consistent with the plan.

Staff believe the project can meet the applicable demolition and conditional use standards.

RECOMMENDATION

The Planning Division recommends that the Plan Commission find that the demolition and conditional use standards are met and **approve** a demolition permit and conditional use for an office building to allow for the construction a dental office building, subject to input at the public hearing and the following conditions:

1. Comments from reviewing agencies.
2. That the applicant work with Planning staff and revise the Yellowstone Drive elevation to improve the street presence of this facade. The applicant should utilize larger windows that extend closer to the ground or provide other design treatments to address this concern.



Department of Public Works
City Engineering Division

608 266 4751

Larry D. Nelson, P.E.
City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
608 264 9275 FAX
1 866 704 2315 Textnet

Deputy City Engineer
Robert F. Phillips, P.E.

Principal Engineers
Michael R. Dailey, P.E.
Christina M. Bachmann, P.E.
John S. Fahrney, P.E.
Gregory T. Fries, P.E.

Facilities & Sustainability
Jeanne E. Hoffman, Manager
James C. Whitney, A.I.A.

Operations Manager
Kathleen M. Cryan

Hydrogeologist
Joseph L. DeMorett, P.G.

GIS Manager
David A. Davis, R.L.S.

Financial Officer
Steven B. Danner-Rivers

DATE: September 5, 2008

TO: Plan Commission

FROM: Larry D. Nelson, P.E., City Engineer

SUBJECT: 344 South Yellowstone Drive Conditional Use and Demolition

The City Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

- | |
|---|
| <p>1. Any damage to the pavement on Mineral Point Road will require restoration in accordance with the Patching Criteria.</p> |
|---|

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

Engineering Division Review of Planned Community Developments, Planned Unit Developments and Conditional Use Applications.

Name: 344 South Yellowstone Drive Conditional Use and Demolition

General

- 1.1 The construction of this building will require removal and replacement of sidewalk, curb and gutter and possibly other parts of the City's infrastructure. The applicant shall enter into a City / Developer agreement for the improvements required for this development. The applicant shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The applicant shall meet with the City Engineer to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. The developer shall sign the Developer's Acknowledgement prior to the City Engineer signing off on this project.
- 1.2 The site plan shall identify lot and block numbers of recorded Certified Survey Map or Plat.
- 1.3 The site plan shall include all lot/ownership lines, existing building locations, proposed building additions, demolitions, parking stalls, driveways, sidewalks (public and/or private), existing and proposed signage, existing and proposed utility locations and landscaping.
- 1.4 The site plan shall identify the difference between existing and proposed impervious areas.
- 1.5 The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
- 1.6 Submit a PDF of all floor plans to Lori Zenchenko lzenchenko@cityofmadison.com so that a preliminary interior addressing plan can be developed. If there are any changes pertaining to the location of a unit, the deletion or addition of a unit, or to the location of the entrance into any unit, (before, during, or after construction) the

10



addresses may need to be changed. The interior address plan is subject to the review and approval of the Fire Marshal.

- 1.7 The site plan shall include a full and complete legal description of the site or property being subjected to this application.
- 1.8 The Developer is required to pay Impact Fees for this development. The Developer shall indicate the method of payment as provided below:
 - 1) Impact Fees shall be paid in full prior to Engineering sign-off of the plat/csm.
 - 2) The Developer has elected to defer the payments until such time as the building permits are applied for, in which case the owner(s) shall receive the invoices to pay the outstanding impact fees at the time of permit issuance. The following shall be required prior to plat sign off;
 - a) The Developer shall supply an Excel spreadsheet with lot numbers, lot areas, and number of dwelling units per lot. The Developer shall supply a CADD file of the proposed FINAL plat, in a format compatible with Microstation J. This information shall be required to calculate the Impact Fees, which will then be recorded at the Register of Deeds against each lot in the subdivision..
 - b) All information shall transmitted to Janet Dailey by e-mail at Jdailey@cityofmadison.com, or on a CD to:

Janet Dailey
City of Madison Engineering Division
210 Martin Luther King Jr. Blvd
Room 115
Madison, WI 53703
 - c) A minimum of three (3) weeks shall be required for staff to calculate the Impact Fees and record the documents prior to plat sign-off.

The Developer shall put the following note on the face of the plat:

LOTS / BUILDINGS WITHIN THIS SUBDIVISION / DEVELOPMENT ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE AT THE TIME BUILDING PERMIT(S) ARE ISSUED.

Right of Way / Easements

- 2.1 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.2 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.3 The Applicant shall Dedicate a Permanent Limited Easement for grading and sloping _____ feet wide along _____.
- 2.4 The City Engineer has reviewed the need for pedestrian and bicycle connections through the development and finds that no connections are required.
- 2.5 The Applicant shall Dedicate a Permanent Limited Easement for a pedestrian / bicycle easement _____ feet wide from _____ to _____.
- 2.6 The Developer shall provide a private easement for public pedestrian and bicycle use through the property running from _____ to _____.
- 2.7 The developer shall be responsible for the ongoing construction and maintenance of a path within the easement. The maintenance responsibilities shall include, but not be limited to, paving, repaving, repairing, marking and plowing. The developer shall work with the City of Madison Real Estate Staff to administer this easement. Applicable fees shall apply.
- 2.8 The Public Sanitary Sewer Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
 - a. The property owner reserves the right to use and occupy the Public Sanitary Sewer Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public sanitary sewer facilities.
 - b. No above-ground improvements shall be located in the Public Sanitary Sewer Easement Area(s) by the City or the property owner, with the exception that grates, sewer access structure (SAS) covers, and other access points to the public sanitary sewer facilities shall be permitted at grade level. (Optional: and with the exception that pavement and/or concrete for driveway purposes shall be permitted.)

10

- c. Plantings and landscaping within the Public Sanitary Sewer Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
- d. The property owner shall not change the grade of the Public Sanitary Sewer Easement Area(s) without the prior written approval of the City's Engineering Division.
- e. The Public Sanitary Sewer Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

- 2.9 The Public Sidewalk Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
 - a. The property owner reserves the right to use and occupy the Public Sidewalk Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public sidewalk improvements.
 - b. No above-ground improvements will be allowed in the Public Sidewalk Easement Area(s) by the property owner. (Optional: with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
 - c. Plantings and landscaping within the Public Sidewalk Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
 - d. The property owner shall not change the grade of the Public Sidewalk Easement Area(s) without the prior written approval of the City's Engineering Division.
 - e. The Public Sidewalk Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

- 2.10 The Public Storm Sewer Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
 - a. The property owner reserves the right to use and occupy the Public Storm Sewer Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public storm sewer facilities.
 - b. No above-ground improvements shall be located in the Public Storm Sewer Easement Area(s) by the City or the property owner, with the exception that grates, sewer access structure (SAS) covers, and other access points to the public storm sewer facilities shall be permitted at grade level. (Optional: and with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
 - c. Plantings and landscaping within the Public Storm Sewer Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
 - d. The property owner shall not change the grade of the Public Storm Sewer Easement Area(s) without the prior written approval of the City's Engineering Division.
The Public Storm Sewer Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

- 2.11 The Public Water Main Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
 - a. The property owner reserves the right to use and occupy the Public Water Main Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public water main facilities.
 - b. No above-ground improvements will be allowed in the Public Water Main Easement Area(s) by the property owner. (Optional: with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
 - c. Plantings and landscaping within the Public Water Main Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
 - d. The property owner shall not change the grade of the Public Water Main Easement Area(s) without the prior written approval of the City's Engineering Division.
 - e. The Public Water Main Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

Streets and Sidewalks

- 3.1 The Applicant shall execute a waiver of notice and hearing on the assessments for the improvement of [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
- 3.2 **Value of sidewalk installation over \$5000.** The Applicant shall Construct Sidewalk to a plan approved by the City Engineer along _____.
- 3.3 **Value of sidewalk installation under \$5000.** The Applicant shall install public sidewalk along _____. The Applicant shall obtain a Street Excavation Permit for the sidewalk work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. All work must be completed within six months or the succeeding June 1, whichever is later. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.4 The Applicant shall execute a waiver of their right to notice and hearings on the assessments for the installation of

- 3.5 The Applicant shall grade the property line along _____ to a grade established by the City Engineer. The grading shall be suitable to allow the installation of sidewalk in the future without the need to grade beyond the property line. The Applicant shall obtain a Street Excavation permit prior to the City Engineer signing off on this development. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.6 The Applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
- 3.7 **Value of the restoration work less than \$5,000. When computing the value, do not include a cost for driveways. Do not include the restoration required to facilitate a utility lateral installation.** The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.8 The Applicant shall make improvements to _____ in order to facilitate ingress and egress to the development. The improvement shall include a (Describe what the work involves or strike this part of the comment.) _____
- 3.9 The Applicant shall make improvements to _____. The improvements shall consist of _____
- 3.10 The approval of this Conditional Use does not include the approval of the changes to roadways, sidewalks or utilities. The applicant shall obtain separate approval by the Board of Public Works and the Common Council for the restoration of the public right of way including any changes requested by developer. The City Engineer shall complete the final plans for the restoration with input from the developer. The curb location, grades, tree locations, tree species, lighting modifications and other items required to facilitate the development or restore the right of way shall be reviewed by the City Engineer, City Traffic Engineer, and City Forester.
- 3.11 The Applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The Applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development.
- 3.12 The Applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
- 3.13 The Applicant shall obtain a privilege in streets agreement for any encroachments inside the public right of way. The approval of this development does not constitute or guarantee approval of the encroachments.
- 3.14 The Applicant shall provide the City Engineer with the proposed soil retention system to accommodate the restoration. The soil retention system must be stamped by a Professional Engineer. The City Engineer may reject or require modifications to the retention system.
- 3.15 The Applicant shall complete work on exposed aggregate sidewalk in accordance with specifications provided by the city. The stone used for the exposed aggregate shall be approved by the City. The Construction Engineer shall be notified prior to beginning construction. Any work that does not match the adjacent work or which the City Construction Engineer finds is unacceptable shall be removed and replaced.
- 3.16 All work in the public right-of-way shall be performed by a City licensed contractor.
- 3.17 Installation of "Private" street signage in accordance with 10.34 MGO is required.
- 3.18. All street tree locations and tree species within the right of way shall be reviewed and approved by City Forestry. Please submit a tree planting plan (in PDF format) to Dean Kahl, of the City Parks Department - dkahl@cityofmadison.com or 266-4816.

Storm Water Management

- 4.1 The site plans shall be revised to show the location of all rain gutter down spout discharges.
- 4.2 Storm sewer to serve this development has been designed and constructed. The site plans shall be revised to identify the location of this storm sewer and to show connection of an internal drainage system to the existing public storm sewer.
- 4.3 The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used.
- 4.4 The applicant shall show storm water "overflow" paths that will safely route runoff when the storm sewer is at capacity.

- 4.5 The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
- 4.6 The City of Madison is an approved agent of the Department of Commerce. This proposal contains a commercial building and as such, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required.
- 4.7 This development includes multiple building permits within a single lot. The City Engineer and/or the Director of the Inspection Unit may require individual control plans and measures for each building.
- 4.8 If the lots within this site plan are inter-dependent upon one another for stormwater runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the site plan and recorded at the Dane Co Register of Deeds.
- 4.9 Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to:
 - Detain the 2 & 10-year storm events.
 - Detain the 2, 10, & 100-year storm events.
 - Control 40% TSS (20 micron particle) off of new paved surfaces
 - Control 80% TSS (5 micron particle) off of new paved surfaces
 - Provide infiltration in accordance with Chapter 37 of the Madison General Ordinances
 - Provide substantial thermal control.
 - Provide oil & grease control from the first 1/2" of runoff from parking areas.
 - Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website – as required by Chapter 37 of the Madison General Ordinances.

Stormwater management plans shall be submitted and approved by City Engineering prior to signoff.

- 4.10 The plan set shall be revised to show more information on proposed drainage for the site. This shall be accomplished by using spot elevations and drainage arrows or through the use of proposed contours. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement.
- 4.11 A portion of this project comes under the jurisdiction of the US Army Corp of Engineers and WDNR for wetland or flood plain issues. A permit for those matters shall be required prior to construction on any of the lots currently within the jurisdictional flood plain.
- 4.12 The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain only the following data, each on a separate layer name/level number:
 - a) Building Footprints
 - b) Internal Walkway Areas
 - c) Internal Site Parking Areas
 - d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e) Right-of-Way lines (public and private)
 - f) All Underlying Lot lines or parcel lines if unplatted
 - g) Lot numbers or the words "unplatted"
 - h) Lot/Plat dimensions
 - i) Street names

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file.

- 4.13 NR-151 of the Wisconsin Administrative Code will be effective on October 1, 2004. Future phases of this project shall comply with NR 151 in effect when work commences. Specifically, any phases not covered by a Notice of Intent (NOI) received from the WDNR under NR-216 prior to October 1, 2004 shall be responsible for compliance with all requirements of NR-151 Subchapter III. As most of the requirements of NR-151 are currently implemented in Chapter 37 of the Madison General Ordinances, the most significant additional requirement shall be that of infiltration.

NR-151 requires infiltration in accord with the following criteria. For the type of development, the site shall comply with one of the three (3) options provided below:

Residential developments shall infiltrate 90% of the predevelopment infiltration amount, 25% of the runoff from the 2-year post development storm or dedicated a maximum of 1% of the site area to active infiltration practices.

Commercial development shall infiltrate 60% of the predevelopment infiltration amount, 10% of the runoff from the 2-year post development storm or dedicate a maximum of 2% of the site area to active infiltration practices.

- 4.14 The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set.
- PDF submittals shall contain the following information:
- a) Building footprints.
 - b) Internal walkway areas.
 - c) Internal site parking areas.
 - d) Lot lines and right-of-way lines.
 - e) Street names.
 - f) Stormwater Management Facilities.
 - g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).
- 4.15 The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:
- a) SLAMM DAT files.
 - b) RECARGA files.
 - c) TR-55/HYDROCAD/Etc...
 - d) Sediment loading calculations
- if calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.
- 4.16 The area adjacent to this proposed development has a known flooding risk. All entrances shall be 2-feet above the adjacent sidewalk elevation or 1-foot above the 100-year regional flood elevation (whichever is greater). This includes garage entrances.

Utilities General

- 5.1 The Applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The Applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 5.2 The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 5.3 All proposed and existing utilities including gas, electric, phone, steam, chilled water, etc shall be shown on the plan.
- 5.4 The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 5.5 The site plans shall be revised to show the location of existing utilities, including depth, type, and size in the adjacent right-of-way.
- 5.6 The developer shall provide information on how the Department of Commerce's requirements regarding treatment of storm water runoff, from parking structures, shall satisfied prior to discharge to the public sewer system. Additionally, information shall be provided on which system (storm or sanitary) the pipe shall be connected to.

Sanitary Sewer

- 6.1 Prior to approval of the conditional use application, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1). \$100 non-refundable deposit for the cost of inspection of the plugging by City staff; and (2). \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 6.2 All outstanding Madison Metropolitan Sewerage District (MMSD) and City of Madison sanitary sewer connection charges are due and payable prior Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Janet Dailey (608-261-9688) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff.
- 6.3 Each unit of a duplex building shall be served by a separate and independent sanitary sewer lateral.

- 6.4 The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.



Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2986
Madison, Wisconsin 53701-2986
PH 608 266 4761
TTY 866-704-2315
FAX 608 267 1158

July 24, 2008

Rev: September 4, 2008

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer and Parking Manager

SUBJECT: **344 South Yellowstone Drive – Demolish / Conditional Use – Office / Build
New Dentist Office**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

PEDESTRIAN AND BICYCLE TRANSPORTATION REVIEW COMMENTS

2. None

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

3. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), across the street, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
4. A "Stop" sign shall be installed at a height of seven (7) feet at the driveway approach. All signs at the approaches shall be installed behind the property line. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
5. The applicant shall modify design the surface parking areas for stalls and backing up according to Figures II of the ordinance. The applicant should use all 9 ft wide stalls with 24 ft back up. The proposed 8 ft width parking spaces require 26 ft of back up for long-term parking.

6. The parking facility shall be modified to provide for adequate internal circulation for vehicles. This can be accommodated by eliminating a parking stall at the dead ends. The eliminated stall shall be modified to provide a turn around area ten (10) to twelve (12) feet in width and signed "No Parking Anytime."
7. The Developer shall post a deposit and reimburse the City for all costs associated with any modifications to Traffic Signals, Street Lighting, Signing and Pavement Marking, and conduit and handholes, including labor, engineering and materials for both temporary and permanent installations.
8. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: John Bieno
Fax: 608-257-1092
Email: jjbieno@tjkdesignbuild.com

DCD: DJM: dm

**CITY OF MADISON
INTERDEPARTMENTAL
CORRESPONDENCE**

Date: September 15, 2008

To: Plan Commission
From: Patrick Anderson, Assistant Zoning Administrator
Subject: 344 South Yellowstone Drive

Present Zoning District: C-2

Proposed Use: Demolish of office building and build a new dental clinic building

Conditional Use: 28.04(22) The demolition of principal buildings requires Plan Commission approval.

1. Provide a reuse/recycling plan, to be reviewed and approved by The City's Recycling Coordinator, Mr. George Dreckmann, prior to a demolition permit being issued.
2. Provide four bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. The bike racks shall be securely anchored to the ground or building to prevent the racks from moving. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area.
3. Submitted landscape plan does not match the site plan. For parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. Note: The landscape points worksheet has been changed regarding point value of landscape elements. Please get a new copy from us. The required trees to not count toward the point total.
4. Lighting is not required. However, if it is provided, it must comply with the attached ordinance. Lighting will be limited to .08 watts per square foot.
5. The site shares a zoning district boundary with a residential development to the west and north. This development must provide effective 6' – 8' high screening along the lot line of this commercial district adjoining a residential zoning district.
6. Meet all applicable State accessible requirements, including but not limited to:

- a) Provide a minimum of two accessible stalls striped per State requirements. A minimum of one of the stalls shall be a van accessible stall 8' wide with an 8' striped out area adjacent.
- b) Show signage at the head of the stalls. Accessible signs shall be a minimum of 60" between the bottom of the sign and the ground.
- c) Show the accessible path from the stalls to the building. The stalls shall be as near the accessible entrance as possible. Show ramps, curbs, or wheel stops where required.

ZONING CRITERIA

Bulk Requirements	Required	Proposed
Lot Area	6,000 sq. ft.	20,628 sq. ft.
Lot width	50'	110.04'
Usable open space	Na	Na
Front yard	25'/25 from residential	Adequate
Side yards	5' (residential side)	12'/50'
Rear yard	10'	70'
Floor area ratio	3.0	Less than 1.0
Building height	---	1 story

Site Design	Required	Proposed
Number parking stalls	15	25
Accessible stalls	2	2 (6)
Loading	n/a	1- 10' x 35'
Number bike parking stalls	4	5 (2)
Landscaping	Yes	(3) & (5)
Lighting	No	(4)

Other Critical Zoning Items	
Urban Design	No
Historic District	No
Landmark building	No
Flood plain	No
Utility easements	Yes
Barrier free (ILHR 69)	Yes

With the above conditions, the proposed project **does** comply with all of the above requirements.



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295
Phone: 608-266-4484 • FAX: 608-267-1153

DATE: 9/5/08
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **344 S. Yellowstone Dr.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. All portions of the exterior walls of newly constructed public buildings and places of employment and open storage of combustible materials shall be within 500-feet of at least TWO fire hydrants. Distances are measured along the path **traveled by the fire truck as the hose lays off the truck**. See MGO 34.20 for additional information.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan