



Department of Planning & Community & Economic Development  
**Planning Division**

Website: [www.cityofmadison.com](http://www.cityofmadison.com)

Madison Municipal Building  
215 Martin Luther King, Jr. Boulevard  
P.O. Box 2985  
Madison, Wisconsin 53701-2985  
TDD 608 266-4747  
FAX 608 266-8739  
PH 608 266-4635

September 21, 2011  
Revised September 26, 2001

Gary A. Brown, FASLA  
University of Wisconsin - Madison  
610 Walnut Street, Suite 919  
Madison, WI 53726

RE: Conditional Use approval for **1635 Kronshage Drive** to construct a new student dormitory and remodel a food service facility

Dear Mr. Brown:

At its September 19, 2011 meeting, the Plan Commission, meeting in regular session, approved your conditional use application to construct a new student dormitory and food service facility at 2000 Observatory Drive, subject to the conditions below. In order to receive final approval of the conditional use and for the conditional use to be in effect, the following conditions must be met and this letter signed and returned to the Zoning Administrator:

**Please contact Janet Dailey, City Engineering Division, at 261-9688 if you have questions regarding the following four (4) items:**

1. City Engineering will review and approve the erosion control plan but will not issue a permit as this is a DOA Project.
2. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
3. All outstanding Madison Metropolitan Sewerage District (MMSD) and City of Madison sanitary sewer connection charges are due and payable prior Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Janet Dailey (608-261-9688) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
4. "The proposed dorm room numbers are non-sequential in the plan set. In accordance with 10.34 MGO – STREET NUMBERS - Submit a PDF of each floor plan to Engineering Mapping Lori Zenchenko ([Lzenchenko@cityofmadison.com](mailto:Lzenchenko@cityofmadison.com)) so that a final addressing plan (interior/exterior) may be developed and implemented. If there are any changes pertaining to the location of units, the deletion or addition of units, or to the location of the entrance into any unit, (before, during or after construction) the addresses may need to be changed. The interior address plan is subject to the review and approval of the Fire Marshal."

**Please contact Bryan Walker, Traffic Engineering Division, at 267-8754 if you have questions regarding the following item:**

5. This is a State of Wisconsin project, the applicant could note on the plan sheet or submit a letter to Traffic Engineering, City Of Madison "The parking stalls design is according to State of Wisconsin parking design standards and approved by the State of Wisconsin".

**Please contact Patrick Anderson, Assistant Zoning Administrator, at 266-5978 if you have any questions regarding the following four (4) items:**

6. Lighting is required. The lighting plans must comply with City of Madison General Ordinances Section 10.085 outdoor lighting standards. (See parking lot packet). Lighting will be limited to .10 watts per square foot. Contact Fred Rehbein at 608.267.8688 for assistance.
7. If bike parking is provided it should comply with City of Madison General Ordinances Section 28.11. There is no predetermined requirement for bike parking. Adequate bike and moped parking have been proposed as per the Campus master plan. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.
8. Meet all applicable State accessible requirements.
9. Parking & Loading shall comply with City of Madison General Ordinances Section 28.11 (4). Provide 10'x 35' loading areas with 14' vertical clearance to be shown on the plan. The loading area shall be exclusive of drive aisle and maneuvering space.

**Please contact Bill Sullivan, Madison Fire Department, at 261-9658 if you have any questions regarding the following item:**

10. Provide an unobstructed vertical clearance of 13'6" above fire access roads including Kronshage Drive. Existing tree branches may need to be trimmed to accommodate this requirement.

**Please now follow the procedures listed below for obtaining your conditional use:**

1. Please submit seven (7) copies of a complete plan set to the Zoning Administrator for final review and comment.
2. This property is not in a Wellhead Protection District. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility. The Water Utility will not need to sign off the final plans, and not need a copy of the approved plans.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting demolition and/or building permit approval.
4. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. This approval shall become null and void one year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within six months of the issuance of said building permit. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use.

If you have any questions regarding obtaining the conditional use approval, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 267-1150.

Sincerely,

Kevin Firchow, AICP  
Planner

cc: Patrick Anderson, Ast. Zoning Administrator  
Janet Dailey, City Engineering  
Bryan Walker, Traffic Engineering  
Bill Sullivan, Fire Department

I hereby acknowledge that I understand and will comply with the above conditions of approval for this conditional use.

\_\_\_\_\_  
*Signature of Applicant*

\_\_\_\_\_  
*Signature of Property Owner (if not the applicant)*

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Firchow)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other: