



Department of Planning & Community & Economic Development
Planning Division

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266-4747
FAX 608 266-8739
PH 608 266-4635

June 5, 2013

Arlan Kay
Architecture Network, Inc
116 East Dayton Street
Madison, WI 53703

RE: Approval of a conditional use at **2501 East Springs Drive and 4824 High Crossing Boulevard** to construct an automobile sales facility and lot as part of an existing Planned Commercial Site

Dear Mr. Kay:

At its June 3, 2013 meeting, the Plan Commission, meeting in regular session, approved your client's request for a conditional use to construct an automobile sales facility and lot as part of an existing Planned Commercial Site. In order to receive final approval of the conditional use and for permits to be issued, the following conditions must be met:

Please contact Janet Dailey, City Engineering Division, at 261-9688 if you have questions regarding the following fourteen (14) items.

1. In accordance with the existing Declaration of Easements documents 4019710 and 4117205 and the supplemental private joint driveway agreement document 4445224, the owner of 2501 East Springs Dr (Lot 3, CSM 11320) shall notify all other owners/parties of the private joint driveway agreement. Per terms of documents cited above, all affected parties are entitled to review and approve the proposed site plan improvements for 2501 East Springs Dr and sign-off on the final geometric configuration of the private driveway as well as approve the final private joint driveway easement. Said easement document to be recorded in the Office of the Dane County, Wisconsin Register of Deeds.
2. Prior to final permit of occupancy, record the deed transferring the property from Annamark Group Z LLC to DMG Holding Company LLC.
3. Revise the plans to show the existing public storm and sanitary sewer facilities along with the limits of the easement. The City Engineer may have additional comments after this information is provided. Include details of the proposed "underground stormwater management" area.
4. This property is subject to the City's Lien Road Sanitary Interceptor area charges. The current rate for this fee is \$3.90/1000 sf.
5. The applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction. (POLICY)

6. All work in the public right-of-way shall be performed by a City licensed contractor. (MGO 16.23(9)(c)5) and MGO 23.01)
7. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
8. Effective January 1, 2010, The Department of Commerce's authority to permit commercial sites, with over one (1) acre of disturbance, for stormwater management and erosion control has been transferred to the Department of Natural Resources (WDNR). The WDNR does not have an authorized local program transferring this authority to the City of Madison. The City of Madison has been required by the WDNR to continue to review projects for compliance with NR216 and NR-151 but a separate permit submittal is now required to the WDNR for this work as well. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process.

As this site is greater than one (1) acre, the applicant is required by State Statute to obtain a Water Resources Application for Project Permits (WRAPP) from the Wisconsin Department of Natural Resources, prior to beginning construction. This permit was previously known as a Notice of Intent Permit (NOI). Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm> (NOTIFICATION)

9. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to a) Control 80% TSS (5 micron particle) off of new paved surfaces; b) Provide infiltration in accordance with Chapter 37 of the Madison General Ordinances; c) Provide oil & grease control from the first 1/2" of runoff from parking areas; and d) Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website – as required by Chapter 37 of the Madison General Ordinances.
10. The plan set shall be revised to show more information on proposed drainage for the site. This shall be accomplished by using spot elevations and drainage arrows or through the use of proposed contours. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement. (POLICY)
11. The applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain only the following data, each on a separate layer name/level number: a) building footprints, b) internal walkway areas, c) internal site parking areas, d) other miscellaneous impervious areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.), e) right-of-way lines (public and private), f) all underlying lot lines or parcel lines if unplatted, g) lot numbers or the words "unplatted", h) lot/plat dimensions, i) street names, and all other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email file transmissions preferred addressing@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file. (POLICY and MGO 37.09(2) & 37.05(4))

12. The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2)) PDF submittals shall contain the following information: a) building footprints, b) internal walkway areas, c) internal site parking areas, d) lot lines and right-of-way lines, e) Street names, f) Stormwater Management Facilities, and g) detail drawings associated with stormwater management facilities (including if applicable planting plans).
13. The applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including: a) SLAMM DAT files; b) RECARGA files; c) TR-55/HYDROCAD/Etc... and d) Sediment loading calculations.
14. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)

Please contact Eric Halvorson, Traffic Engineering Division, at 266-6572 if you have questions regarding the following four (4) items.

15. Applicant shall define thru travel way between rear inventory and entrance to garage bays. This may be accomplished through the use of a different construction material in the areas shown as buffers or the use of mountable raised pavement in the areas shown as buffers.
16. When the applicant shall submit plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing and proposed property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), adjacent driveway approaches to lots on either side and across the street, signage, percent of slope, semitrailer movements and vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'. Contact City Traffic Engineering if you have questions.
17. The developer shall post a deposit and reimburse the City for all costs associated with any modifications to Traffic Signals, Street Lighting, Signing and Pavement Marking, and conduit and handholes, including labor, engineering and materials for both temporary and permanent installations.
18. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact Patrick Anderson, Zoning at 266-5978 if you have questions regarding the following seven (7) items.

19. The site is being developed as part of a Planned Commercial Site. Per Sec. 28.04(23) a Planned Commercial Site shall have a plan and reciprocal land use agreement approved by the Traffic Engineer, City Engineer and Director of Planning and Development recorded in the Office of the Dane County Register of Deeds. An existing planned commercial site may not be changed without approval by the Traffic Engineer, City Engineer and Director of Planning and Development or approval of the Plan Commission.
20. For parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. Note: The landscape points worksheet has been changed regarding point value of landscape elements. Please get a new copy from us. The required trees to not count toward the point total.

21. Lighting is required and shall be in accordance with City of Madison General Ordinances Section 10.085. Provide a lighting photometric plan, including cut sheets for fixture, with the final plan submittal.
22. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes and Chapter 33 Urban Design District ordinances of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.
23. Bike parking shall comply with City of Madison General Ordinances Section 28.11.
24. Provide a minimum of two bike parking spaces in a safe and convenient location on an impervious surface to be shown on the final plan. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Provide details of the proposed bike rack.
25. Parking requirements for persons with disabilities must comply with City of Madison General Ordinances Section 28.11 (3) 6.(m) which includes all applicable State accessible requirements, including but not limited to:
 - a. Provide the minimum accessible stalls striped per State requirements. A van accessible stall shall be 8' wide with an 8' striped out area adjacent.
 - b. Show signage at the head of the stalls. Accessible signs shall be a minimum of 60" between the bottom of the sign and the ground.
 - c. Show the accessible path from the stalls to the building. The stalls shall be as near the accessible entrance as possible. Show ramps, curbs, or wheel stops where required.

Please contact Bill Sullivan, Madison Fire Department, at 261-9658 if you have questions regarding the following item.

26. The Madison Fire Department does not object to this proposal provided the project complies with all applicable fire codes and ordinances.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

The applicant is also required to satisfy the conditions of approval of the Urban Design Commission prior to the final staff approval of the project and the issuance of building permits. Please contact Al Martin, Urban Design Commission Secretary, at 267-8740 if you have any questions about those conditions.

Please now follow the procedures listed below:

1. Please revise your plans per the above conditions and submit nine (9) copies of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.

2. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility. This property is not in a Wellhead Protection District. The Water Utility will not need to sign off the final plans, and not need a copy of the approved plans.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting demolition permit approval.
4. The approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use, demolition or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 267-1150.

Sincerely,

Kevin Firchow, AICP
Planner

cc: Janet Dailey, City Engineering Division
Eric Halvorson, Traffic Engineering Division
Bill Sullivan, Fire Department
Patrick Anderson, Zoning

I hereby acknowledge that I understand and will comply with the above conditions of approval for this conditional use.

Signature of Applicant

Signature of Property Owner (if not the applicant)

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Firchow)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other: