



Department of Planning & Community & Economic Development
Planning Division

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266-4747
FAX 608 266-8739
PH 608 266-4635

July 15, 2013

Randy Bruce
Knothe and Bruce Architects, LLC
7601 University Avenue, Suite 201
Middleton, Wisconsin 53562

RE: Approval of a demolition permit and conditional use to allow demolition of an auto repair shop at 2620 Monroe Street and a single-family residence at 665 Knickerbocker Street and construction of a mixed-use building containing approximately 2,300 square feet of first floor retail space and 21 apartments.

Dear Mr. Bruce;

At its July 8, 2013 meeting, the Plan Commission found the standards met and **approved** your client's demolition permit and conditional use requests for 2620 Monroe Street and 665 Knickerbocker Street. The conditions of approval in the following sections shall be satisfied prior to issuance of demolition or building permits for the project.

However, an appeal to the granting of the conditional use for this project was filed with the City on July 12, 2013. Therefore, please consider this letter to be a preliminary letter of approval pending resolution of the appeal. A final letter will be issued for this project based on the disposition of the appeal of the conditional use approval.

The conditions of approval for this demolition permit and conditional use as of July 8, 2013 are:

Please contact Janet Dailey of the City Engineering Division at 261-9688 if you have questions regarding the following twenty-two (22) items:

1. The proposed building will cross underlying platted lot lines. Current City enforcement of State building codes requires the underlying platted lot lines be dissolved by Certified Survey Map (CSM) prior to issuance of a building permit. The related CSM for this property shall be completed and recorded with the Dane County Register of Deeds prior to issuance of building permits.
2. The address of 2620 Monroe Street is being retired with the demolition of the existing building. The base address for the proposed apartments is 2624 Monroe Street. The commercial space will have an address of 2630 Monroe Street.
3. A pumping and groundwater management plan shall be submitted to the City Engineering Division for approval both for pumping during construction and for permanent pumping of the building.

4. The construction of this building will require removal and replacement of sidewalk, curb and gutter and possibly other parts of the City's infrastructure. The applicant shall enter into a City / Developer agreement for the improvements required for this development. The applicant shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The applicant shall meet with the City Engineer to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. The developer shall sign the Developer's Acknowledgement prior to the City Engineer signing off on this project.
5. In accordance with 10.34 MGO – Street Numbers: When site plans are final, submit a PDF of each floor plan to Lori Zenchenko in Engineering Mapping (Lzenchenko@cityofmadison.com) so that an interior addressing plan can be developed. If there are any changes pertaining to the location of a unit, the deletion or addition of a unit, or to the location of the entrance into any unit, (before, during or after construction) the addresses may need to be changed. The interior address plan is subject to the review and approval of the Fire Marshal.
6. The applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
7. The approval of this development does not include the approval of the changes to roadways, sidewalks or utilities. The applicant shall obtain separate approval by the Board of Public Works and the Common Council for the restoration of the public right of way including any changes requested by developer. The City Engineer shall complete the final plans for the restoration with input from the developer. The curb location, grades, tree locations, tree species, lighting modifications and other items required to facilitate the development or restore the right of way shall be reviewed by the City Engineer, City Traffic Engineer, and City Forester.
8. The applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development.
9. The applicant shall replace all sidewalk and curb and gutter abutting the property, which is damaged by the construction, or any sidewalk and curb and gutter that the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
10. All work in the public right of way shall be performed by a City-licensed contractor.
11. All street tree locations and tree species within the right of way shall be reviewed and approved by City Forestry. Please submit a tree planting plan (in PDF format) to Dean Kahl, of the Parks Division - dkahl@cityofmadison.com or 266-4816. Approval and permitting of any tree removal or replacement shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan.
12. All damage to the pavement on Monroe Street and Knickerbocker Street adjacent to this development shall be restored in accordance with the City's Pavement Patching Criteria.
13. The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used.

14. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
15. For commercial sites less than 1 acre in disturbance, the City of Madison is an approved agent of the Department of Commerce and Wisconsin Department of Natural Resources (WDNR). As this project is on a site with disturbance area less than one acre and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required.
16. Prior to approval, this project shall comply with MGO Section 37 regarding stormwater management. Specifically, this development is required to: reduce TSS off of the proposed development by 80% when compared with the existing site, and; complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website as required by Chapter 37 MGO.
17. The applicant shall submit, prior to plan sign-off, digital CAD files to the Land Records Coordinator in the City Engineering Division. (Lori Zenchenko) lzenchenko@cityofmadison.com. The digital copies shall be drawn to scale and represent final construction including: building footprints, internal walkway areas, internal site parking areas, lot lines/ numbers/ dimensions, street names, and other miscellaneous impervious areas. All other levels (contours, elevations, etc) are not to be included with this file submittal. E-mail file transmissions are preferred. The digital CAD file shall be to scale and represent final construction. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format. Please include the site address in this transmittal.
18. The applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management File including: SLAMM DAT files; RECARGA files; TR-55/HYDROCAD/etc., and; sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.
19. The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction.
20. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.
21. Prior to final approval of the demolition permit, the owner shall obtain a permit to plug each existing sanitary sewer and/ or storm sewer lateral that serves a building that is proposed for demolition. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing lateral that serves a building which is proposed for demolition. For each lateral to be plugged, the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. Note: New plugging procedures and permit fees are in effect as of January 1, 2013.

22. City of Madison Environmental Projects staff has reviewed the subject site and determined that a Phase I ESA **will** be required of the applicant. The applicant shall provide one digital and two hard copies of an ASTM Phase I ESA prepared by an environmental professional. Staff review of this Phase I ESA will determine if a further investigative Phase II ESA is also required. Please submit any relevant Phase I and Phase II ESAs to Brynn Bemis (267-1986, bbemis@cityofmadison.com) for further review.

Please contact Dennis Cawley of the Madison Water Utility at 261-9243 if you have any questions regarding the following item:

23. The Madison Water Utility shall be notified to remove the water meter prior to demolition. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.

Please contact Eric Halvorson of the Traffic Engineering Division at 266-6527 if you have any questions regarding the following five (5) items:

24. A condition of approval shall be that no residential parking permits shall be issued for 2620 Monroe Street, as would be consistent with other projects in the area. In addition, the applicant shall inform all tenants of this facility of the restriction in their apartment leases. The applicant shall submit a copy of the lease for the project noting this condition in the lease when submitting plans for City approval.
25. The applicant shall provide a deposit for the installation of overhead pedestrian signage on Monroe Street to provide improved pedestrian crossing for the additional pedestrians generated by the development. The timeframe of installation will be determined by the City Traffic Engineer.
26. When the applicant shall submit plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing and proposed property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), adjacent driveway approaches to lots on either side and across the street, signage, percent of slope, semitrailer movements and vehicle routes, dimensions of radii, aisles, driveways, stalls including the 2 feet overhang, and a scaled drawing at 1" = 20'. Contact City Traffic Engineering if you have questions.
27. The developer shall post a deposit and reimburse the City for all costs associated with any modifications to traffic signals, street lighting, signing and pavement marking, and conduit and handholes, including labor, engineering and materials for both temporary and permanent installations.
28. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have any questions regarding the following item:

29. Provide fire apparatus access as required by IFC 503 2009 edition, MGO Section 34.503, as follows:
- The site plans shall clearly identify the location of all fire lanes.
 - IFC 503 Appendix D105: Provide an aerial apparatus access fire lane that is at least 26 feet wide, with the near edge of the fire lane within 30 feet and not closer than 15 feet from the structure, and parallel to one entire side of the structure, if any part of the building is over 30 feet in height.

Please contact Pat Anderson, Assistant Zoning Administrator, at 266-5978 if you have any questions regarding the following seven (7) items:

30. Provide a reuse/recycling plan, to be reviewed and approved by the City's Recycling Coordinator, George Dreckmann, prior to a demolition permit being issued. Section 28.185(7)(a)5 of the Zoning Ordinance requires the submittal of documentation demonstrating compliance with the approved reuse and recycling plan. Please note, the owner must submit documentation of recycling and reuse within 60 days of completion of demolition.
31. Off street parking requirements shall comply with Section 28.141(5) of the Zoning Code: The submitted plans reflect that the proposal is 5 parking spaces deficient of the required number of spaces for the non-residential uses; however, that number is within the administrative parking adjustment approval range.
32. Provide the minimum side yard setback of 6 feet from the northeastern property line on the final set of plans.
33. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with MGO Section 31, Sign Code prior to sign installations.
34. Bike parking shall comply with MGO Section 28.141(4)(g), Table 28I-3: Provide required bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. Note: A bike-parking stall is 2 feet by 6 feet with a 5-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices. Provide details of bike rack on final plan sets.
35. Provide landscape plans pursuant to Sec. 28.142, Landscape Plan and Design Standards. The plans should include but are not limited to: Landscape plans for zoning lots greater than 10,000 square feet in size must be prepared by a registered landscape architect. Screening shall be provided alongside and rear property boundaries between commercial, mixed use or industrial districts and residential districts. Screening shall consist of a solid wall, solid fence, or hedge with year-round foliage, between 6 and 8 feet in height, except that within the front yard setback area, screening shall not exceed 4 feet in height. Height of screening shall be measured from natural or approved grade.
36. Parking requirements for persons with disabilities must comply with Section 28.141(4)e of the Zoning Code. The provisions contained in Wis. Stat. §§ 101.12, 346.503, and 346.56 and any related Wisconsin Administrative Code sections are hereby adopted by reference in the Zoning Code and made applicable to all parking facilities whenever constructed.

Please contact Kay Rutledge of the Parks Division at 266-4714 if you have any questions regarding the following four (4) items:

37. The developer shall pay \$ 49,421.40 in park impact fees (2013 fees in lieu of parkland dedication and for park development) for the 21 multi-family units proposed less a credit of \$3,687.96 for the existing single-family residence to be demolished. The developer must select a method for payment of the **\$45,733.44** of park fees due before signoff on the new building. This development is within the Vilas-Brittingham park impact fee district (SI27). Please reference ID# 13136 when contacting Parks Division staff about this project.

38. Approval of the plans for this project does not include any approval to prune, remove or plant trees in the public right of way. Permission for such activities must be obtained from the City Forester, 266-4816. All proposed street tree removals within the right of way shall be reviewed by City Forestry. Please submit an existing inventory of trees (location, species, & DBH) and a tree removal plan (in PDF format) to Dean Kahl – dkahl@cityofmadison.com. Approval and permitting of street tree removals shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan.
39. Additional street trees are needed for this project. All street tree planting locations and trees species with the right of way shall be reviewed by City Forestry. Please submit a tree planting plan (in PDF format) to Dean Kahl – dkahl@cityofmadison.com. Approval and permitting of tree planting shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan. Tree planting specifications can be found in Section 209 of *City of Madison Standard Specifications for Public Works Construction*.
40. Existing street trees shall be protected. Please include the following note on the site plan: Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is necessary, the contractor shall contact City Forestry (266-4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry. Tree protection specifications can be found in Section 107.13 of *City of Madison Standard Specifications for Public Works Construction*

Please contact my office at 261-9632 if you have any questions about the following five (5) items, including the three conditions added by the Plan Commission (43-45):

41. Revise the plans prior to final staff approval and issuance of demolition and building permits to clearly identify the window materials to be used on each elevation and to show the distant mass of the building in shadow on the side elevations where applicable.
42. Provide a screening plan for the project be submitted for approval that shows how all mechanical equipment and utility equipment located above ground will be screened in accordance with the requirements of the Zoning Code, including the location, size and placement of all rooftop-, building- and ground-mounted mechanical equipment.
43. That if the utility box (proposed on the north side of the building) cannot be relocated inside the building, and determined to produce noise, the applicant shall screen the box for noise.
44. That the openings on the garage on the northwest corner of the building be closed in for the purpose of noise mitigation.
45. That the applicant preserves as many of the existing trees in the northeast corner of the site in the 20-foot rear yard as possible. The emphasis is to preserve native trees, noting that the Siberian Elms could be removed.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. After the plans have been revised per the above conditions, please file **nine (9) sets** of complete, fully dimensioned, and to-scale plans, the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval.
3. Provide a reuse/recycling plan, to be reviewed and approved by the City Recycling Coordinator prior to a demolition permit being issued. Section 28.185(10) of the Zoning Ordinance requires the submittal of documentation demonstrating compliance with the approved reuse and recycling plan. Please note, the owner must submit documentation of recycling and reuse within 60 days of completion of demolition.
4. The Madison Water Utility shall be notified to remove the water meter(s) prior to demolition.
5. Approval of the plans for this project does not include any approval to prune, remove or plant trees in the public right of way. Permission for such activities must be obtained from the City Forester, 266-4816.
6. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void one (1) year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 261-9632.

Sincerely,

Timothy M. Parks
Planner

cc: Janet Dailey, City Engineering Division
Eric Halvorson, Traffic Engineering Division
Matt Tucker, Zoning Administrator
Dennis Cawley, Madison Water Utility
Bill Sullivan, Madison Fire Department
Kay Rutledge, Parks Division

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (T. Parks)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other:

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.

Signature of Applicant

*Signature of Property Owner
(If Not Applicant)*