



Department of Planning & Community & Economic Development

Planning Division

Katherine Cornwell, Director

Madison Municipal Building, Suite LL-100

215 Martin Luther King, Jr. Boulevard

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

Fax (608) 267-8739

www.cityofmadison.com

May 6, 2015

John Seamon

Iconica

901 Deming Way

Madison, WI 53717

RE: Approval of a demolition permit to construct a multi-tenant commercial tenant building at
3825 East Washington Avenue

Dear Mr. Seamon:

At its May 4, 2015 meeting the Plan Commission, meeting in regular session, approved your client's request for a demolition permit raze an existing restaurant building to construct a multi-tenant commercial tenant building at 3825 East Washington Avenue. In order to receive final approval and for permits to be issued, the following conditions must be met:

Please contact Janet Schmidt, Engineering Division at 261-9688 if you have questions regarding the following twenty-four (24) items:

1. The address of 3825 E Washington Ave will be retired with the demolition of the building. This submittal reconfigures the proposed building and now has three tenant spaces. The address for Erik's Bike Shop is 3813 E Washington Ave. The address for "Tenant B" is 3817 E Washington Ave. The address for "Tenant C" is 3821 E Washington Ave.
2. The existing private storm sewer connects to the private storm sewer system on the adjacent site to the east. This site will also rely upon the adjacent parcel for surface drainage and storm sewer connection. A recorded copy of the executed private storm water drainage / storm sewer agreement/easement shall be provided prior to the issuance of a building permit for any new construction on this site.
3. A retaining wall reaching a height of approximately six feet is planned to run longitudinally within the public sanitary sewer easements recorded as document numbers 1005923 and 998714. A Consent to Occupy Easement document shall be drafted and recorded to define responsibilities and requirements in conjunction with the proposed improvements proposed within this easement. A City of Madison Real Estate project will be required along with a \$500 for administrative fee to create the document, obtain required approval(s) and record with the Register of Deeds. Coordinate with and provide legal descriptions and map exhibits along with the \$500 for administrative fees to Jeff Quamme at jrquamme@cityofmadison.com or 1600 Emil Street, Madison, WI 53703 (Ph. 608-266-4097).

4. The address of 3825 E Washington Ave will be retired with the demolition of the building. The address for Erik's Bike Shop is 3813 E Washington Ave. The address for "Tenant B" is 3819 E Washington Ave.
5. The proposed new building will cross an underlying platted lot line (O.L. 92A). Current fire code and City enforcement requires the underlying platted lot line be dissolved by Certified Survey Map (CSM) prior to issuance of a building permit. A CSM and required supporting information shall be prepared and submitted to the City of Madison Planning Department. The CSM shall be approved by the City and recorded with the Dane County Register of Deeds prior to issuance of a building permit.
6. Applicant shall show existing 20-foot wide sanitary sewer easement on the utility plan. City sewer will need to remain in service. The Credit Union at the corner of East Washington and Mendota Street is connected to sewer running through 3825 East Washington Avenue lot development.
7. The proposed landscaping shall not obstruct the existing sewer access cover.
8. The applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass. (POLICY)
9. Value of the restoration work less than \$5,000. When computing the value, do not include a cost for driveways. Do not include the restoration required to facilitate a utility lateral installation. The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. (MGO 16.23(9)(d)(6) This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
10. The applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction. (POLICY)
11. All work in the public right-of-way shall be performed by a City licensed contractor. (MGO 16.23(9)(c)5) and MGO 23.01)
12. All street tree locations and tree species within the right of way shall be reviewed and approved by City Forestry. Please submit a tree planting plan (in PDF format) to Dean Kahl, of the City Parks Department - dkahl@cityofmadison.com or 266-4816. Approval and permitting of any tree removal or replacement shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan. (POLICY)
13. All damage to the pavement on East Washington Avenue, adjacent to this development shall be restored in accordance with the City of Madison's Pavement Patching Criteria. For additional information please see the following link: <http://www.cityofmadison.com/engineering/patchingCriteria.cfm> (POLICY)

14. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in the ROCK RIVER TMDL ZONE and by Resolution 14-00043 passed by the City of Madison Common Council on 1/21/2014. You will be expected to meet a higher standard of erosion control than the minimum standards set by the WDNR.
15. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
16. For Commercial sites < 1 acre in disturbance the City of Madison is an approved agent of the Department of Commerce and WDNR. As this project is on a site with disturbance area less than one (1) acres, and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required. (NOTIFICATION)
17. If the lots within this site plan are inter-dependent upon one another for stormwater runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the site plan and recorded at the Dane Co Register of Deeds. (POLICY)
18. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to a) Reduce TSS off of the proposed development by 80% when compared with the existing site and b) Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website – as required by Chapter 37 of the Madison General Ordinances.
19. The applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Division (mapping). The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number: a) Building Footprints, b) Internal Walkway Areas, c) Internal Site Parking Areas, d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.), e) Right-of-Way lines (public and private), f) Plat name and lot lines (metes & bounds parcel lines if unplatted), g) Platted lot numbers (noted “unplatted lands” if not platted), h) Lot/Plat property dimensions, i) Street names

All other levels (contours, elevations, etc) are not to be included with this file submittal.

THE CAD FILE WILL ONLY BE REQUIRED PRIOR TO FINAL PLAN REVIEW SO THAT MULTIPLE FILES DO NOT NEED TO BE SUPPLIED OR REVIEWED.

20. The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2)) PDF submittals shall contain the following information: a) building footprints, b) internal walkway areas, c) internal site parking areas, d) lot lines and right-of-way lines,

- e) Street names, f) Stormwater Management Facilities, and g) detail drawings associated with stormwater management facilities (including if applicable planting plans).
21. The applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including: a) SLAMM DAT files, b) RECARGA files, c) TR-55/HYDROCAD/Etc..., and d) Sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided. (POLICY and MGO 37.09(2))
22. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. NOTE: As of January 1, 2013 new plugging procedures and permit fees go into effect. The new procedures and revised fee schedule is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
23. All outstanding Madison Metropolitan Sewerage District (MMSD) are due and payable prior Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Janet Schmidt (608-261-9688) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
24. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)

Please contact Eric Halvorson, Traffic Engineering at 266-6527 if you have questions regarding the following five (5) items:

25. Applicant shall not receive deliveries with vehicles larger than 35'. Doing so would jeopardize public safety and impede traffic flow on East Washington Avenue. Any damage to public infrastructure as a result of violating this condition will be the responsibility of the property owner.
26. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
27. The developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
28. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.

29. All parking facility design shall conform to MGO standards, as set in section 10.08(6). This will require the driveway to be modified to conform with the Madison Standard Commercial Drive Detail (drawing 3.09)

Please contact Matt Tucker, Zoning Administrator at 266-4569 if you have questions regarding the following ten (10) items:

30. Sec. 28.185 (7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Mr. George Dreckmann. (608-267-2626).
31. Sec. 28.185 (10) Every person who is required to submit a reuse and recycling plan pursuant to Sec. 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
32. Section 28.185(9) (a) A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
33. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances prior to sign installations.
34. Bike parking for tenant spaces shall comply with City of Madison General Ordinances Table 28I-3 (General Regulations). Bicycle parking shall be located in a safe and convenient location on an impervious surface. A bicycle parking stall shall be 2 feet by 6 feet with a 5 foot clear access aisle. Provide a detail of the bicycle rack. Identify and dimension required stalls and access areas on the final plan sets.
35. Pursuant to Sec. 28.142(3) Landscape Plan and Design Standards: Landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
36. Exterior lighting provided shall be in accordance with City of Madison General Ordinances Section 10.085. Provide an exterior lighting plan and fixture cut sheets, with the final plan submittal.
37. No rooftop mechanical equipment is shown on submitted plans. Per Sec. 28.060(2)(f) and 28.142(9)(d), any rooftop equipment shall be screened from view.
38. Provide detail for refuse enclosure per sec. 28.142(9)(a).
39. Provide detail of door and or window openings on final plans. Per Sec. 28.060 (2)(d), Provide final calculations on elevation sheets to determine the door and window opening percentage.

Please contact Bill Sullivan, Madison Fire Department at 261-9658 if you have questions regarding the following two (2) items:

40. Madison Fire Department recommends the installation of an automatic fire sprinkler system to protect the owner's investment and allow greater flexibility in use of the building.
41. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Lt Scott Bavery (608) 576-0600.

Please contact Kay Rutledge, Parks Division at 266-4714 if you have questions regarding the following three (3) items:

42. Forestry will permit the removal of two trees (10" Elm & 4" Tree Lilac) for the new driveway locations. Contractor shall contact Forestry at least one week prior to tree removal to obtain a City Forestry Tree Removal Permit.
43. Additional street trees are needed for this project. All street tree planting locations and trees species with the right of way shall be reviewed by City Forestry. Please submit a site plan (in PDF format) to Dean Kahl – dkahl@cityofmadison.com or 266-4816. Approval and permitting of tree planting shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2013/Part2.pdf>
44. The existing 18" Honeylocust street tree, west of the east driveway shall be protected. Please include the following note on the site plan: Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is necessary, contractor shall contact City Forestry (266-4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry. Tree protection specifications can be found in section 107.13 of City of Madison Standard Specifications for Public Works Construction - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2013/Part1.pdf>.
45. Please reference ID# 15106 when contacting Parks about this project.

Please contact my office at 267-1150 if you have questions regarding the following item:

46. That the plans submitted for sign off depict the location of the existing sanitary sewer easement and that no trees or large shrubs shall be placed within that easement. The City Engineering Division must also approve the plantings within the sanitary sewer easement.

The applicant is also required to satisfy the conditions of approval of the Urban Design Commission prior to the final staff approval of the project and the issuance of building permits. Please contact Al Martin, Urban Design Commission Secretary, at 267-8740 if you have any questions about those conditions.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your demolition permit:

1. Please revise your plans per the above conditions and submit eleven (11) copies of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. The Madison Water Utility shall be notified to remove the water meters prior to demolition. This property is not in a wellhead protection district. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility. The Water Utility will not need to sign off the final plans, and will not need a copy of the approved plans.
3. Approval of plans for this project does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, 266-4816.
4. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
5. A reuse and recycling plan approved by the Recycling Coordinator is required by ordinance prior to the issuance of a wrecking permit. The reuse and recycling plan shall be submitted along with the resubmittal of site plans for forwarding to the Recycling Coordinator.
6. The approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
7. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.

3825 East Washington Avenue

May 6, 2015

Page 8

If you have any questions regarding obtaining your conditional use, demolition, or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 267-1150.

Sincerely,

Kevin Firchow, AICP
Planner

cc: Janet Schmidt, City Engineering Division
Eric Halvorson, Traffic Engineering Division
Bill Sullivan, Fire Department
Patrick Anderson, Zoning
Kay Rutledge, Parks Division

I hereby acknowledge that I understand and will comply with the above conditions of approval for the demolition permit.

Signature of Applicant

Signature of Property Owner (if not the applicant)

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Firchow)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other: