

CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: April 3, 2008
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **1102 Willow Ln.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

None

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

1. As required by MGO 10.34 and IFC 505.1, all residential and commercial buildings must have the approved address posted. The address numbers shall be 4 inches in height, numbers shall be in contrast to the background and visible from the street.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan