



# CITY OF MADISON FIRE DEPARTMENT

## Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: 9/6/05  
TO: Plan Commission  
FROM: Edwin J. Ruckriegel, Fire Marshal  
SUBJECT: **317-319 W. Gorham St.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. Per the IFC chapter 10 and MGO34:
  - a. Applicant shall post the capacity of the outside dining area in accordance International Fire Code 2003 edition.
  - b. Proposed deck shall not be located at, adjacent, or obstruct the required exits from the building.
  - c. Provide and maintain exits from the deck in accordance with the International Fire Code 2003 edition.
  - d. Submit a seating plan for the proposed deck space.

## **GENERAL OR STANDARD REVIEW COMMENTS**

In addition, we offer the following General or Standard Review Comments:

- e. All exiting shall be shown all the way to the public way.

Please contact John Lippitt, MFD Fire Protection Engineer, at 608-261-9658 if you have questions regarding the above items.

cc: John Lippitt