

CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295 Phone: 608-266-4484 • FAX: 608-267-1153

ARTHURS	Filolic. 008-200-4484 • FAA. 008-207-1133
DATE:	August 8, 2007
TO:	Plan Commission
FROM:	Edwin J. Ruckriegel, Fire Marshal
SUBJECT:	34 Schroeder Ct.
The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:	
MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)	
None.	

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

- Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows: (commercial structures only)
 - a. The site plans shall clearly identify the location of all fire lanes.
 - b. Provide a completed MFD "Fire Apparatus Access and Fire Hydrant Worksheet" with the site plan submittal.
- 2. All portions of the exterior walls of newly constructed public buildings and places of employment and open storage of combustible materials shall be within 500-feet of at least TWO fire hydrants. Distances are measured along the path **traveled by the fire truck as the hose lays off the truck.** See MGO 34.20 for additional information.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan