



# CITY OF MADISON FIRE DEPARTMENT

---

## Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: 4/25/05  
TO: Plan Commission  
FROM: Edwin J. Ruckriegel, Fire Marshal  
SUBJECT: **4309 Green Ave.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None.

## **GENERAL OR STANDARD REVIEW COMMENTS**

In addition, we offer the following General or Standard Review Comments:

2. All portions of the exterior walls of newly constructed one- and two-family dwellings shall be within 500-feet of at least one fire hydrant. Distances are measured along the path **traveled by the fire truck as the hose lays off the truck.** See MGO 34.20 for additional information.

Please contact John Lippitt, MFD Fire Protection Engineer, at 608-261-9658 if you have questions regarding the above items.

cc: John Lippitt