



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: 8/11/06
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **4601 American Pkwy.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. Per the IFC chapter 10 and MGO34:
 - a. Applicant shall post the capacity of the outside dining area in accordance International Fire Code 2006 edition.
 - b. Proposed deck, patio or fenced in area shall not be located at, adjacent or obstruct the required exits from the building.
 - c. Provide and maintain exits from the deck, patio or fenced in area in accordance with the International Fire Code 2006 edition.
 - d. Submit a seating plan for the proposed deck, patio or fenced in area space.

Please contact John Lippitt, MFD Fire Protection Engineer, at 608-261-9658 if you have questions regarding the above items.

cc: John Lippitt