



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: 4/25/05
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **725 S. Gammon Rd.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

1. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows:
 - a. The site plans shall clearly identify the location of all fire lanes.
 - b. Provide a completed MFD "Fire Apparatus Access and Fire Hydrant Worksheet" with the site plan submittal.

Please contact John Lippitt, MFD Fire Protection Engineer, at 608-261-9658 if you have questions regarding the above items.

cc: John Lippitt