



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295
Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: 4/25/05
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **7436 Mineral Point.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. The Madison fire department does not object to this outdoor eating area as long as all required exiting from the building is maintained and proper exiting from the outside eating area away from the building is maintained.
3. Also note that an emergency evacuation plan should be completed for this area as well as any updates needed for the inside eating area.

Please contact John Lippitt, MFD Fire Protection Engineer, at 608-261-9658 if you have questions regarding the above items.

cc: John Lippitt