



# CITY OF MADISON FIRE DEPARTMENT

## Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: June 28, 2007

TO: Plan Commission

FROM: Edwin J. Ruckriegel, Fire Marshal

SUBJECT: **8001 Raymond Road**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

No comments.

## **GENERAL OR STANDARD REVIEW COMMENTS**

In addition, we offer the following General or Standard Review Comments:

1. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows: **(commercial structures only)**
  - a. The site plans shall clearly identify the location of all fire lanes.
  - b. Provide an aerial apparatus access fire lane that is at least 26-feet wide, with the near edge of the fire lane within 30-feet of the structure, and parallel to one entire side of the structure, if any part of the building is over 30 feet in height.
  - c. Provide a fire lane that extends to within 150-feet of all exterior portions of the structure, or it can be extended to within 250-feet if the building is fully sprinklered.
  - d. A dead-end fire lane that is longer than 150-feet shall terminate in a turnaround. Provide an approved turnaround (cul-de-sac, 45 degree wye, 90 degree tee) at the end of a fire lane that is more than 150-feet in length.
  - e. Provide a minimum unobstructed width of 26-feet for at least 20-feet on each side of the fire hydrant.
2. All portions of the exterior walls of newly constructed public buildings and places of employment and open storage of combustible materials shall be within 500-feet of at least TWO fire hydrants. Distances are measured along the path **traveled by the fire truck as the hose lays off the truck**. See MGO 34.20 for additional information.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan