

## **CITY OF MADISON FIRE DEPARTMENT**

**Fire Prevention Division** 

325 W. Johnson St., Madison, WI 53703-2295 Phone: 608-266-4484 • FAX: 608-267-1153

DATE: August 3, 2007

TO: Plan Commission

FROM: Edwin J. Ruckriegel, Fire Marshal

## SUBJECT: 821 South Gammon Road

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

none

## **GENERAL OR STANDARD REVIEW COMMENTS**

In addition, we offer the following General or Standard Review Comments:

- 1. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows: *(commercial structures only)* 
  - a. The site plans shall clearly identify the location of all fire lanes.
  - b. Provide a fire lane that extends to within 150-feet of all exterior portions of the structure, or it can be extended to within 250-feet if the building is fully sprinklered.
  - c. All portions of the exterior walls of newly constructed one- and two-family dwellings shall be within 500-feet of at least one fire hydrant. Distances are measured along the path **traveled by the fire truck as the hose lays off the truck.** See MGO 34.20 for additional information.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan