



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: February 4, 2008
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **89 East Towne Mall**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows:
 - a. The site plans shall clearly identify the location of all fire lanes.
2. Per the IFC chapter 10 and MGO34:
 - a. Applicant shall submit approved capacity with the site plan and post the capacity of the outside dining area in accordance International Fire Code 2006 edition.
 - b. Proposed deck, patio or fenced in area shall not be located at, adjacent or obstruct the required exits from the building.
 - c. Provide and maintain exits from the deck, patio or fenced in area in accordance with the International Fire Code 2006 edition.
 - d. Submit a seating plan for the proposed deck, patio or fenced in area space.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

3. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows:
 - a. Provide a completed MFD "Fire Apparatus Access and Fire Hydrant Worksheet" with the site plan submittal.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan