

CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295 Phone: 608-266-4484 • FAX: 608-267-1153

DATE: March 14, 2007

TO: Plan Commission

FROM: Edwin J. Ruckriegel, Fire Marshal

SUBJECT: 910 W. Wingra Dr.

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as
follows: Provide an aerial apparatus access fire lane that is at least 26-feet wide, with
the near edge of the fire lane within 30-feet of the structure, and parallel to one entire
side of the structure.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

- 2. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows: The site plans shall clearly identify the location of all fire lanes.
- 3. All portions of the exterior walls of newly constructed public buildings and places of employment and open storage of combustible materials shall be within 500-feet of at least TWO fire hydrants. Distances are measured along the path traveled by the fire truck as the hose lays off the truck. See MGO 34.20 for additional information.

Please contact Scott Strassburg, Fire Code Enforcement Officer at 608-261-9843 if you have questions regarding the above items.