



## **Madison Metro Transit System**



1101 East Washington Avenue  
Madison, Wisconsin 53703  
Administrative Office: 608 266 4904  
Fax: 608 267 8778

November 11, 2005

TO: Plan Commission

FROM: Timothy Sobota, Transit Planner, Metro Transit

SUBJECT: **702 North Midvale Boulevard – SIP Amendment #1 – Hilldale Restaurant**

Metro Transit has reviewed the subject development and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. The applicant shall install a concrete passenger boarding pad on the west side of Midvale Boulevard, approximately 100 feet south of University Avenue, generally opposite the accessible pedestrian walkway. The concrete pad shall occupy the full distance of the terrace, measure 6 feet in width parallel to the street, and lie flush between the sidewalk and the top of curb.
2. The developer shall install and maintain a bench or other seating amenity and a trash receptacle on the property side of the sidewalk, to either side of the accessible pedestrian walkway apron.
3. The developer shall include the location of this concrete passenger boarding pad and the passenger amenities on the final documents filed with their permit application so that Metro Transit may review and approve the design.


### **GENERAL OR STANDARD REVIEW COMMENTS**

In addition, we offer the following General or Standard Review Comments:

4. Metro Transit has proposed to initiate bus service seven days a week along Midvale Boulevard between University Avenue and the Heather Crest access road along the south mall frontage, effective March of 2006. Metro bus stop #2286 would be installed on the west side of the Midvale Boulevard, approximately 100 feet south of University Avenue.
5. Metro Transit requests to sign and review final documents submitted for this project.

Please contact Tim Sobota, Metro Transit at 261-4289  
or by email at <tsobota@cityodmadison.com>  
if you have questions regarding the above items.

CC: Project contact person, Dennis Harder: dharder@jfreed.com (email)  
*Atch: Notated site plan*



Seating and trash site options

Concrete passenger boarding pad site

Site Layout Plan  
 Hilldale PUD-GDP-SIP Amendment #1  
 Restaurant / Water Feature

----- Exter