



## Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100  
215 Martin Luther King, Jr. Boulevard  
P.O. Box 2986  
Madison, Wisconsin 53701-2986  
PH 608 266 4761  
TTY 866-704-2315  
FAX 608 267 1158

November 9, 2006

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer and Parking Manager

SUBJECT: **1502 Parkside Street – Rezoning – M1 to C3L – Church**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

### PEDESTRIAN AND BICYCLE TRANSPORTATION REVIEW COMMENTS

2. Applicant shall install sidewalk on frontage as part of development. As other sites improve, sidewalk will connect in future.
3. Applicant needs to check with Zoning Administrator on bicycle parking requirements.

### GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

4. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
5. The applicant shall prevent encroachment onto adjacent land areas and sidewalk by barriers of some type, which shall be noted on the face of the revised plans.

6. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person:

Mail to: Larry Sain  
424 S. Park St.  
Madison WI 53715

Fax:

Email:

DCD: DJM: dm