



## Traffic Engineering Division

David C. Dryer, City Traffic Engineer

Madison Municipal Building  
215 Martin Luther King, Jr. Boulevard  
P.O. Box 2986  
Madison, Wisconsin 53701-2986  
PH 608/266-4761  
TTY 608/267-9623  
FAX 608/267-1158

March 23, 2006

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer

SUBJECT: **4226 Owl Creek Drive – Conditional Use – Four (4) Unit Condominium Building**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

## GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
3. The intersection shall be so designed so as not to violate the City's sight-triangle preservation requirement which states that on a corner lot no structure, screening, or embankment of any kind shall be erected, placed, maintained or grown between the heights of 30 inches and 10 feet above the curb level or its equivalent within the triangle space formed by the two intersecting street lines or their projections and a line joining points on such street lines located a minimum of 25 feet from the street intersection in order to provide adequate vehicular vision clearance.
4. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Doug Nelson  
Fax: 244-0205  
Email: [doug@thenelsongroup.org](mailto:doug@thenelsongroup.org)

DCD:DJM:dm