



## Traffic Engineering Division

David C. Dryer, City Traffic Engineer

Madison Municipal Building  
215 Martin Luther King, Jr. Boulevard  
P.O. Box 2986  
Madison, Wisconsin 53701-2986  
PH 608/266-4761  
TTY 608/267-9623  
FAX 608/267-1158

November 10, 2005

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer

SUBJECT: **614 Bear Claw Way – Conditional Use – Eight (8) Condominium Units**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

## GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), adjacent driveway approaches to lots on either side and across the street, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
3. When site plans are submitted for approval, the developer shall provide recorded copies of the joint driveway ingress/egress and crossing easements.
4. A "Stop" signs shall be installed at a height of seven (7) feet at all driveway approaches. All signs at the approaches shall be installed behind the property line. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
5. The applicant shall show the dimensions for lot 2 proposed surface parking stalls items A, B, C, D, E, and F, and for ninety-degree angle parking with nine (9) foot wide stalls and backing up, according to Figures II "Medium and Large Vehicles" parking design

standards in Section 10.08(6)(b) 2. (If two (2) feet of overhang are used for a vehicle, it shall be shown on the plan.)

6. The Developer shall post a deposit and reimburse the City for all costs associated with any modifications to Traffic Signals, Street Lighting, Signing and Pavement Marking, and conduit and handholes, including labor, engineering and materials for both temporary and permanent installations.
7. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: David Hull  
Fax: 848-2938  
Email: homesbychl@aol.com

DCD:DJM:dm