



## Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100  
215 Martin Luther King, Jr. Boulevard  
P.O. Box 2986  
Madison, Wisconsin 53701-2986  
PH 608 266 4761  
TTY 866-704-2315  
FAX 608 267 1158

September 20, 2007

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer and Parking Manager

SUBJECT: **6733 Fairhaven Road – Rezoning – PUD (GDP) to PUD (SIP) – 12 Unit Townhouse**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

### PEDESTRIAN AND BICYCLE TRANSPORTATION REVIEW COMMENTS

2. None

### GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

3. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
4. Per ordinance, the small car stalls shall not exceed 25% of the total number of Medium and Large Vehicles and Small Vehicles stalls for the facility. The site plan shall show small car parking spaces identified and properly controlled with a sign "Small Cars Only" per each space, when plans are submitted for approval.
5. A "Stop" sign shall be installed at a height of seven (7) feet at all driveway approaches. All signs at the approaches shall be installed behind the property line. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.

6. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Casey Louthier

Fax: 608-437-1201

Email: doo2ep-x@tds.net

DCD: DJM: dm