

Date: July 1, 2008
To: The Plan Commission
From: Larry D. Nelson P.E., Interim General Manager
Subject: DEMOLITION – 1500 Williamson Street

The Madison Water Utility has reviewed this demolition request and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

None

GENERAL OR STANDARD REVIEW COMMENTS

The Madison Water Utility shall be notified to remove the water meter prior to demolition.

All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.

This property is not in a Wellhead Protection District.

The Water Utility will need to sign off the final plans, but will not need a copy of the approved plans.

Larry D. Nelson, P.E.

