

Date: June 16, 2008

To: The Plan Commission

From: Larry D. Nelson P.E., Interim General Manager

Subject: DEMOLITION / REZONING – 2317-2423 Allied Drive
4705-4713 Jenewein Road
4654 Crescent Road

The Madison Water Utility has reviewed this demolition / rezoning request and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

None

GENERAL OR STANDARD REVIEW COMMENTS

The Madison Water Utility shall be notified to remove the water meters prior to demolition.

This property is not in a Wellhead Protection District.

All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.

The Water Utility will sign off the final plans, but will not need a copy of the approved plans.

Larry D. Nelson, P.E.