

**CITY OF MADISON  
MADISON WATER UTILITY  
119 East Olin Avenue  
266-4651**

**MEMORANDUM**

**Date:** April 10, 2006

**To:** The Plan Commission  
**From:** Dennis M. Cawley, Engineer 4 - Water Utility  
**Subject:** PRELIMINARY PLAT / REZONING – Badger Mill Creek

The Madison Water Utility has reviewed this preliminary plat / rezoning and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS**

Certain properties located on proposed Street “C” may need individual booster pumps due to the elevation of the lots.

**GENERAL OR STANDARD REVIEW COMMENTS**

All public water mains and water service laterals shall be installed by standard City of Madison Subdivision Contract.

All operating private wells shall be identified and permitted by the Water Utility in accordance with Madison General Ordinance 13.21

All unused private wells shall be abandoned in accordance with Madison General Ordinance 13.21.

The Water Utility will not need to sign off the final plans, but will need a copy of the approved plans.

Dennis M. Cawley

