

**CITY OF MADISON
MADISON WATER UTILITY
119 East Olin Avenue
266-4651**

MEMORANDUM

Date: March 8, 2007

To: The Plan Commission
From: Dennis M. Cawley, Engineer 4 - Water Utility
Subject: PRELIMINARY/FINAL PLAT / REZONING - Midtown Center

The Madison Water Utility has reviewed this preliminary/final plat / rezoning and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

The proposed Utility Plan does not meet the Madison Water Utility Rules and Regulations. Each lot of record shall have a separate water service lateral connected to a public water main.

GENERAL OR STANDARD REVIEW COMMENTS

None

The Water Utility will not need to sign off the final plans, but will need a copy of the approved plans.

Dennis M. Cawley