

**CITY OF MADISON  
MADISON WATER UTILITY  
119 East Olin Avenue  
266-4651**

**MEMORANDUM**

**Date:** September 11, 2006

**To:** The Plan Commission  
**From:** Dennis M. Cawley, Engineer IV - Water Utility  
**Subject:** REZONING – 9401 Midtown Road

Madison Water Utility has reviewed this rezoning and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS**

None

**GENERAL OR STANDARD REVIEW COMMENTS**

The proposed looped water main across proposed Lot 1 of the Hawks Ridge Plat is required to be a public water main unless installed with check valves in accordance with State Administrative Code NR 811.08(1).

The Water Utility will not need to sign off the final plans, nor need a copy of the approved plans.

Dennis M. Cawley