

**CITY OF MADISON
MADISON WATER UTILITY
119 East Olin Avenue
266-4651**

MEMORANDUM

Date: August 15, 2007

To: The Plan Commission
From: Dennis M. Cawley, Engineer 4 - Water Utility
Subject: PRELIMINARY / FINAL PLAT – Hawks Ridge

The Madison Water Utility has reviewed this preliminary / final plat and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

None

GENERAL OR STANDARD REVIEW COMMENTS

There is an unassessed water main adjacent to this property on Mid Town Road.

All public water mains and water service laterals shall be installed by standard City of Madison Subdivision Contract.

All operating private wells shall be identified and permitted by the Water Utility in accordance with Madison General Ordinance 13.21

All unused private wells shall be abandoned in accordance with Madison General Ordinance 13.21.

The Water Utility will not need to sign off the final plans, but will need a copy of the approved plans.

Dennis M. Cawley

