

**CITY OF MADISON
INTERDEPARTMENTAL
CORRESPONDENCE**

Date: January 12, 2006

To: Plan Commission
From: Kathy Voeck, Assistant Zoning Administrator
Subject: **2 East Park Ct.**

Present Zoning District: C-2

Proposed Use: Auto Rental Facility (Enterprise Rent-A-Car)

Conditional Use: 28.09(3)(d)14 Automobile rental agencies are a conditional use

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE.**

GENERAL OR STANDARD REVIEW COMMENTS

1. Automobile rental agencies are a conditional use provided there is direct vehicular access to a heavy traffic route system.
2. The handicap accessible signs shall be erected so that the bottom of the sign is 5' above grade.
3. Provide a minimum of two bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. The lockable enclosed lockers or racks or equivalent structures in or upon which the bicycle may be locked by the user shall be securely anchored to the ground or building to prevent the lockers or racks from being removed from the location. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.
4. Parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note: The required trees do not count toward the landscape point total.) Planting islands shall consist of at least 75% vegetative cover, including trees, shrubs, ground cover, and/or grass. Up to 25% of the island surface may be brick pavers, mulch or other non-vegetative cover. All plant materials in islands shall be protected from vehicles by concrete curbs.

2 Eastpass Ct.

C:\cp pdfs_new\EastParkCt2_011206.doc

5. Lighting is not required. However, if it is provided, it must comply with City of Madison outdoor lighting standards. (See parking lot packet). Lighting will be limited to .08 watts per square foot.
6. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 of the Madison General Ordinances. Permits must be issued by the Zoning Section of the Department of Planning and Development

ZONING CRITERIA

Bulk Requirements	Required	Proposed
Lot Area	6,000 sq. ft.	60,584 sq. ft.
Lot width	50'	297'
Usable open space	n/a	n/a
Front yard	0'	50'
Side yards	0'	adequate
Rear yard	10'	70'
Floor area ratio	3.0	less than 1.0
Building height	---	1 story

Site Design	Required	Proposed
Number parking stalls	11 empl/cust stalls + rental stls	14 empl/cust <u>66 rental</u> 80 total
Accessible stalls	1	2 (1)
Loading	n/a	n/a
Number bike parking stalls	2	(3)
Landscaping	Yes	(4)
Lighting	No	(5)

Other Critical Zoning Items	
Urban Design	No
Flood plain	No
Utility easements	No
Barrier free (ILHR 69)	Yes

With the above conditions, the proposed project **does** comply with all of the above requirements.