## CITY OF MADISON INTERDEPARTMENTAL CORRESPONDENCE

**Date:** October 27, 2006

**To:** Plan Commission

From: Kathy Voeck, Assistant Zoning Administrator

**Subject:** 9701 Brader Way

**Present Zoning District: PUD(GDP)** 

Proposed Use: 3 Story 46,062 s.f. office building

**Requested Zoning District:** PUD(SIP)

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE.** 

## GENERAL OR STANDARD REVIEW COMMENTS

- 1. Meet all applicable State accessible requirements, including but not limited to:
  - a. Provide a minimum of **six** accessible stalls striped per State requirements. A minimum of one of the stalls shall be a van accessible stall 8' wide with an 8' striped out area adjacent.
  - b. Show signage at the head of the stalls. Accessible signs shall be a minimum of 60" between the bottom of the sign and the ground.
  - c. Show the accessible path from the stalls to the building. The stalls shall be as near the accessible entrance as possible. Show ramps, curbs, or wheel stops where required.
- 2. Provide **one** 10' x 35' loading areas with 14' vertical clearance to be shown on the plan. The loading area shall be exclusive of drive aisle and maneuvering space.
- 3. Provide 17 bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. The lockable enclosed lockers or racks or equivalent structures in or upon which the bicycle may be locked by the user shall be securely anchored to the ground or building to prevent the lockers or racks from being removed from the location. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.

9701 Brader Way

- 4. Parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note: The required trees do not count toward the landscape point total.) Planting islands shall consist of at least 75% vegetative cover, including trees, shrubs, ground cover, and/or grass. Up to 25% of the island surface may be brick pavers, mulch or other non-vegetative cover. All plant materials in islands shall be protected from vehicles by concrete curbs.
- 5. Lighting is not required. However, if it is provided, it must comply with City of Madison outdoor lighting standards. (See parking lot packet). Lighting will be limited to .08 watts per square foot.
- 6. The plan sheets shall be consistent, parking stall configuration, accessible stall locations, drive aisles, etc.
- 7. Provide a PUD(SIP) zoning text that is site specific to this project. Meet with Zoning/Planning staff regarding the text.

## ZONING CRITERIA

Zolvilvo ChilEkili			
<b>Bulk Requirements</b>	Required	Proposed	
Lot Area	6,000 sq. ft.	81,062 sq. ft.	
Lot width	50'	adequate	·
Usable open space	n/a	n/a	
Front yard	0'	12'	
Side yards	0' (zoning)	12 & 82'	
Through Lot (rear)	0'	155'	
Floor area ratio	3.0	less than 1.0	
Building height		3 stories	

Site Design	Required	Proposed
Number parking stalls	154	136 surface
		39 garage
		175 total
Accessible stalls	6	(1)
Loading	1 (10' x 35') area	(2)
Number bike parking stalls	17	(3)
Landscaping	Yes	(4)
Lighting	No	(5)

9701 Brader Way

October 27, 2006

C:\cp pdfs\_new\BraderWay9701\_102506.doc

Page 3

Other Critical Zoning Items	
Urban Design	Yes
Historic District	No
Landmark building	No
Flood plain	No
Utility easements	yes
Water front development	No
Adjacent to park	No
Barrier free (ILHR 69)	Yes

With the above conditions, the proposed project **does** comply with all of the above requirements.

<sup>\*</sup> Since this project is being rezoned to the (PUD) district, and there are no predetermined bulk requirements, we are reviewing it based on the criteria for the C-2 district, because of the surrounding land uses.