MADISON WATER UTILITY

2025 VOLATILE ORGANIC COMPOUND (VOC) RESULTS

Volatile Organic Compounds	Units	MCL	MCLG	6	6	6	6	6	7	7	7	7	9	9	9	9	11	11	11	11	12	13	14	14	15
	Sample Date			1/3	1/13	4/9	7/14	10/13	1/3	5/21	7/15	10/13	1/3	4/4	7/15	10/13	1/3	4/4	7/15	10/13	1/3	4/4	1/13	4/9	9/3
Benzene	ppb	5	zero	<0.11	<0.11	<0.17	<0.17	<0.17	<0.11	<0.17	<0.17	<0.17	<0.11	<0.17	<0.17	<0.17	<0.11	<0.17	<0.17	<0.17	<0.11	<0.17	<0.11	<0.17	<0.17
Bromobenzene	ppb	--	--	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19
Bromodichloromethane*	ppb	80	zero	<0.17	<0.17	<0.23	<0.23	<0.23	**1.2**	**0.88**	**0.77**	**0.85**	**0.61**	**0.60**	**0.54**	**0.79**	<0.17	<0.23	<0.23	<0.23	<0.17	<0.23	**0.18**	<0.23	<0.23
Bromoform*	ppb	80	zero	<0.24	<0.24	<0.24	**0.33**	<0.24	**0.28**	**0.30**	<0.24	<0.24	<0.24	**0.29**	<0.24	**0.43**	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	**0.48**	**0.36**	<0.24
Bromomethane	ppb	--	--	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30
Carbon Tetrachloride	ppb	5	zero	<0.19	<0.19	<0.30	<0.30	<0.30	<0.19	<0.30	<0.30	<0.30	<0.19	<0.30	<0.30	<0.30	<0.19	<0.30	<0.30	<0.30	<0.19	<0.30	<0.19	<0.30	<0.30
Chloroethane	ppb	--	--	<0.13	<0.13	<0.25	<0.25	<0.25	<0.13	<0.25	<0.25	<0.25	<0.13	<0.25	<0.25	<0.25	<0.13	<0.25	<0.25	<0.25	<0.13	<0.25	<0.13	<0.25	<0.25
Chloroform*	ppb	80	--	<0.14	<0.14	<0.24	<0.24	<0.24	**0.80**	**0.63**	**0.63**	**0.60**	**0.40**	**0.27**	**0.28**	**0.30**	<0.14	<0.24	<0.24	<0.24	<0.14	<0.24	**0.25**	<0.24	<0.24
Chloromethane	ppb	--	--	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27
o-Chlorotoluene	ppb	--	--	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21
p-Chlorotoluene	ppb	--	--	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19
Dibromochloromethane*	ppb	80	60	**0.27**	<0.24	<0.24	**0.27**	<0.24	**1.4**	**0.82**	**0.68**	**0.78**	**0.84**	**0.81**	**0.83**	**1.1**	<0.24	**0.25**	<0.24	<0.24	<0.24	<0.24	**0.30**	<0.24	<0.24
Dibromomethane	ppb	--	--	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22
m-Dichlorobenzene (1,3)	ppb	--	--	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28
o-Dichlorobenzene (1,2)	ppb	600	600	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32
p-Dichlorobenzene (1,4)	ppb	75	75	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29
Dichlorodifluoromethane	ppb	--	--	<0.11	<0.11	<0.22	<0.22	<0.22	<0.11	<0.22	<0.22	<0.22	<0.11	<0.22	<0.22	<0.22	<0.11	<0.22	<0.22	<0.22	<0.11	<0.22	<0.11	<0.22	<0.22
1,1-Dichloroethane	ppb	--	--	<0.083	<0.083	<0.21	<0.21	<0.21	<0.083	<0.21	<0.21	<0.21	<0.083	<0.21	<0.21	<0.21	<0.083	<0.21	<0.21	<0.21	<0.083	<0.21	<0.083	<0.21	<0.21
1,2-Dichloroethane	ppb	5	zero	<0.13	<0.13	<0.22	<0.22	<0.22	<0.13	<0.22	<0.22	<0.22	<0.13	<0.22	<0.22	<0.22	<0.13	<0.22	<0.22	<0.22	<0.13	<0.22	<0.13	<0.22	<0.22
1,1-Dichloroethylene	ppb	7	7	<0.14	<0.14	<0.31	<0.31	<0.31	<0.14	<0.31	<0.31	<0.31	<0.14	<0.31	<0.31	<0.31	<0.14	<0.31	<0.31	<0.31	<0.14	<0.31	<0.14	<0.31	<0.31
1,2-Dichloroethylene (cis)	ppb	70	70	<0.15	<0.15	<0.23	<0.23	<0.23	<0.15	**0.26**	**0.38**	**0.29**	<0.15	<0.23	<0.23	<0.23	**0.29**	**0.48**	**0.44**	**0.35**	<0.15	<0.23	<0.15	<0.23	<0.23
1,2-Dichloroethylene (trans)	ppb	100	100	<0.11	<0.11	<0.20	<0.20	<0.20	<0.11	<0.20	<0.20	<0.20	<0.11	<0.20	<0.20	<0.20	<0.11	<0.20	<0.20	<0.20	<0.11	<0.20	<0.11	<0.20	<0.20
Dichloromethane	ppb	5	zero	<0.38	<0.38	<0.38	<0.18	<0.18	<0.38	<0.38	<0.18	<0.18	<0.38	<0.38	<0.18	<0.18	<0.38	<0.38	<0.18	<0.18	<0.38	<0.38	<0.38	<0.38	<0.18
1,2-Dichloropropane	ppb	5	zero	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16
1,3-Dichloropropane	ppb	--	--	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24
2,2-Dichloropropane	ppb	--	--	<0.19	<0.19	<0.24	<0.24	<0.24	<0.19	<0.24	<0.24	<0.24	<0.19	<0.24	<0.24	<0.24	<0.19	<0.24	<0.24	<0.24	<0.19	<0.24	<0.19	<0.24	<0.24
1,1-Dichloropropene	ppb	--	--	<0.18	<0.18	<0.25	<0.25	<0.25	<0.18	<0.25	<0.25	<0.25	<0.18	<0.25	<0.25	<0.25	<0.18	<0.25	<0.25	<0.25	<0.18	<0.25	<0.18	<0.25	<0.25
1,3-Dichloropropene	ppb	--	--	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51
Ethylbenzene	ppb	700	700	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21
Hexachlorobutadiene	ppb	--	--	<0.31	<0.31	<0.36	<0.36	<0.36	<0.31	<0.36	<0.36	<0.36	<0.31	<0.36	<0.36	<0.36	<0.31	<0.36	<0.36	<0.36	<0.31	<0.36	<0.31	<0.36	<0.36
Isopropylbenzene	ppb	--	--	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21
p-Isopropyltoluene	ppb	--	--	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30
Methyl t-butyl ether	ppb	--	--	<0.16	<0.16	<0.24	<0.24	<0.24	<0.16	<0.24	<0.24	<0.24	<0.16	<0.24	<0.24	<0.24	<0.16	<0.24	<0.24	<0.24	<0.16	<0.24	<0.16	<0.24	<0.24
Monochlorobenzene	ppb	100	100	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20
Naphthalene	ppb	--	--	<0.39	<0.39	<0.19	<0.19	<0.19	<0.39	<0.19	<0.19	<0.19	<0.39	<0.19	<0.19	<0.19	<0.39	<0.19	<0.19	<0.19	<0.39	<0.19	<0.39	<0.19	<0.19
Styrene	ppb	100	100	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	**0.43**
1,1,1,2-Tetrachloroethane	ppb	--	--	<0.19	<0.19	<0.31	<0.31	<0.31	<0.19	<0.31	<0.31	<0.31	<0.19	<0.31	<0.31	<0.31	<0.19	<0.31	<0.31	<0.31	<0.19	<0.31	<0.19	<0.31	<0.31
1,1,2,2-Tetrachloroethane	ppb	--	--	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28
Tetrachloroethylene	ppb	5	zero	**2.0**	**2.3**	**2.1**	**2.3**	**2.2**	**1.2**	**0.87**	**0.79**	**0.84**	**0.86**	<0.25	**1.1**	**0.74**	**0.76**	**0.71**	**0.46**	**0.66**	<0.49	<0.25	<0.49	<0.25	<0.25
Toluene	ppb	1000	1000	<0.17	<0.17	<0.20	<0.20	<0.20	<0.17	<0.20	<0.20	<0.20	<0.17	<0.20	<0.20	<0.20	<0.17	<0.20	<0.20	<0.20	<0.17	<0.20	<0.17	<0.20	<0.20
1,2,4-Trichlorobenzene	ppb	70	70	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28
1,1,1-Trichloroethane	ppb	200	200	<0.15	<0.15	<0.23	<0.23	<0.23	<0.15	<0.23	<0.23	<0.23	<0.15	<0.23	<0.23	<0.23	<0.15	<0.23	<0.23	<0.23	<0.15	<0.23	<0.15	<0.23	<0.23
1,1,2-Trichloroethane	ppb	5	3	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21
Trichloroethylene	ppb	5	zero	<0.17	<0.17	<0.22	<0.22	<0.22	**0.31**	**0.36**	**0.28**	**0.24**	<0.17	<0.22	<0.22	<0.22	**0.23**	**0.30**	**0.28**	<0.22	<0.17	<0.22	<0.17	<0.22	<0.22
Trichlorofluoromethane	ppb	--	--	<0.085	<0.085	<0.33	<0.33	<0.33	<0.085	<0.33	<0.33	<0.33	<0.085	<0.33	<0.33	<0.33	**0.43**	<0.33	**0.66**	<0.33	<0.085	<0.33	<0.085	<0.33	<0.33
1,2,3-Trichloropropane	ppb	--	--	<0.42	<0.42	<0.20	<0.20	<0.20	<0.42	<0.20	<0.20	<0.20	<0.42	<0.20	<0.20	<0.20	<0.42	<0.20	<0.20	<0.20	<0.42	<0.20	<0.42	<0.20	<0.20
Trichlortrifluoroethane	ppb	--	--	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22
1,2,4-Trimethylbenzene	ppb	--	--	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26
1,3,5-Trimethylbenzene	ppb	--	--	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23
Vinyl Chloride	ppb	0.2	zero	<0.086	<0.086	<0.18	<0.18	<0.18	<0.086	<0.18	<0.18	<0.18	<0.086	<0.18	<0.18	<0.18	<0.086	<0.18	<0.18	<0.18	<0.086	<0.18	<0.086	<0.18	<0.18
Xylene, Total	ppb	10000	10000	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24

Volatile Organic Compounds	15	15	15	15	16	17	18	18	18	18	18	20	24	25	25	25	26	27	28	29	30	31	Volatile Organic Compounds
	9/16	10/21	11/24	12/16	1/3	7/14	1/3	4/9	5/21	7/15	10/13	1/13	4/4	4/4	7/15	10/13	5/21	1/13	1/3	4/9	1/13	1/13	
Benzene	<0.17	<0.17	<0.17	<0.17	<0.11	<0.17	<0.11	<0.17	<0.17	<0.17	<0.17	<0.11	<0.17	<0.17	<0.17	<0.17	<0.17	<0.11	<0.11	<0.17	<0.11	<0.11	Benzene
Bromobenzene	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	Bromobenzene
Bromodichloromethane*	<0.23	<0.23	<0.23	<0.23	<0.17	**1.4**	**0.17**	**0.25**	<0.23	<0.23	<0.23	<0.17	**1.6**	<0.23	<0.23	<0.23	**0.46**	**0.26**	**0.18**	**0.64**	**0.19**	**0.25**	**Bromodichloromethane***
Bromoform*	<0.24	<0.24	<0.24	<0.24	<0.24	**0.37**	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	**0.26**	<0.24	<0.24	<0.24	**0.36**	**0.50**	<0.24	<0.24	<0.24	<0.24	**Bromoform***
Bromomethane	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	Bromomethane
Carbon Tetrachloride	<0.30	<0.30	<0.30	<0.30	<0.19	<0.30	<0.19	<0.30	<0.30	<0.30	<0.30	<0.19	<0.30	<0.30	<0.30	<0.30	<0.30	<0.19	<0.19	<0.30	<0.19	<0.19	Carbon Tetrachloride
Chloroethane	<0.25	<0.25	<0.25	<0.25	<0.13	<0.25	<0.13	<0.25	<0.25	<0.25	<0.25	<0.13	<0.25	<0.25	<0.25	<0.25	<0.25	<0.13	<0.13	<0.25	<0.13	<0.13	Chloroethane
Chloroform*	<0.24	**0.31**	**1.2**	**1.4**	<0.14	**0.98**	<0.14	<0.24	<0.24	<0.24	<0.24	**0.21**	**0.98**	<0.24	<0.24	<0.24	**0.28**	**0.23**	<0.14	**0.43**	<0.14	<0.14	**Chloroform***
Chloromethane	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	<0.27	Chloromethane
o-Chlorotoluene	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	o-Chlorotoluene
p-Chlorotoluene	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	p-Chlorotoluene
Dibromochloromethane*	<0.24	<0.24	<0.24	<0.24	<0.24	**1.2**	<0.24	<0.24	<0.24	**0.27**	<0.24	<0.24	**1.4**	<0.24	<0.24	<0.24	**0.57**	**0.98**	<0.24	<0.24	<0.24	<0.24	**Dibromochloromethane***
Dibromomethane	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	Dibromomethane
m-Dichlorobenzene (1,3)	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	m-Dichlorobenzene (1,3)
o-Dichlorobenzene (1,2)	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	<0.32	o-Dichlorobenzene (1,2)
p-Dichlorobenzene (1,4)	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	<0.29	p-Dichlorobenzene (1,4)
Dichlorodifluoromethane	<0.22	<0.22	<0.22	<0.22	<0.11	<0.22	<0.11	<0.22	<0.22	<0.22	<0.22	<0.11	<0.22	<0.22	<0.22	<0.22	<0.22	<0.11	<0.11	<0.22	<0.11	<0.11	Dichlorodifluoromethane
1,1-Dichloroethane	<0.21	<0.21	<0.21	<0.21	<0.083	<0.21	<0.083	<0.21	<0.21	<0.21	<0.21	<0.083	<0.21	<0.21	<0.21	<0.21	<0.21	<0.083	<0.083	<0.21	<0.083	<0.083	**1,1-Dichloroethane**
1,2-Dichloroethane	<0.22	<0.22	<0.22	<0.22	<0.13	<0.22	<0.13	<0.22	<0.22	<0.22	<0.22	<0.13	<0.22	<0.22	<0.22	<0.22	<0.22	<0.13	<0.13	<0.22	<0.13	<0.13	1,2-Dichloroethane
1,1-Dichloroethylene	<0.31	<0.31	<0.31	<0.31	<0.14	<0.31	<0.14	<0.31	<0.31	<0.31	<0.31	<0.14	<0.31	<0.31	<0.31	<0.31	<0.31	<0.14	<0.14	<0.31	<0.14	<0.14	**1,1-Dichloroethylene**
1,2-Dichloroethylene (cis)	<0.23	<0.23	<0.23	<0.23	<0.15	<0.23	<0.15	<0.23	<0.23	<0.23	<0.23	<0.15	<0.23	<0.23	<0.23	<0.23	<0.23	<0.15	<0.15	<0.23	<0.15	<0.15	**1,2-Dichloroethylene (cis)**
1,2-Dichloroethylene (trans)	<0.20	<0.20	<0.20	<0.20	<0.11	<0.20	<0.11	<0.20	<0.20	<0.20	<0.20	<0.11	<0.20	<0.20	<0.20	<0.20	<0.20	<0.11	<0.11	<0.20	<0.11	<0.11	1,2-Dichloroethylene (trans)
Dichloromethane	<0.18	<0.18	<0.18	<0.18	<0.38	<0.18	<0.38	<0.38	<0.38	<0.18	<0.18	<0.38	<0.38	<0.38	<0.18	<0.18	<0.38	<0.38	<0.38	<0.38	<0.38	<0.38	Dichloromethane
1,2-Dichloropropane	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	<0.16	1,2-Dichloropropane
1,3-Dichloropropane	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	1,3-Dichloropropane
2,2-Dichloropropane	<0.24	<0.24	<0.24	<0.24	<0.19	<0.24	<0.19	<0.24	<0.24	<0.24	<0.24	<0.19	<0.24	<0.24	<0.24	<0.24	<0.24	<0.19	<0.19	<0.24	<0.19	<0.19	2,2-Dichloropropane
1,1-Dichloropropene	<0.25	<0.25	<0.25	<0.25	<0.18	<0.25	<0.18	<0.25	<0.25	<0.25	<0.25	<0.18	<0.25	<0.25	<0.25	<0.25	<0.25	<0.18	<0.18	<0.25	<0.18	<0.18	1,1-Dichloropropene
1,3-Dichloropropene	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	<0.51	1,3-Dichloropropene
Ethylbenzene	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	Ethylbenzene
Hexachlorobutadiene	<0.36	<0.36	<0.36	<0.36	<0.31	<0.36	<0.31	<0.36	<0.36	<0.36	<0.36	<0.31	<0.36	<0.36	<0.36	<0.36	<0.36	<0.31	<0.31	<0.36	<0.31	<0.31	Hexachlorobutadiene
Isopropylbenzene	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	Isopropylbenzene
p-Isopropyltoluene	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	p-Isopropyltoluene
Methyl t-butyl ether	<0.24	<0.24	<0.24	<0.24	<0.16	<0.24	<0.16	<0.24	<0.24	<0.24	<0.24	<0.16	<0.24	<0.24	<0.24	<0.24	<0.24	<0.16	<0.16	<0.24	<0.16	<0.16	Methyl t-butyl ether
Monochlorobenzene	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	Monochlorobenzene
Naphthalene	<0.19	<0.19	<0.19	<0.19	<0.39	<0.19	<0.39	<0.19	<0.19	<0.19	<0.19	<0.39	<0.19	<0.19	<0.19	<0.19	<0.19	<0.39	<0.39	<0.19	<0.39	<0.39	Naphthalene
Styrene	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	<0.19	Styrene
1,1,1,2-Tetrachloroethane	<0.31	<0.31	<0.31	<0.31	<0.19	<0.31	<0.19	<0.31	<0.31	<0.31	<0.31	<0.19	<0.31	<0.31	<0.31	<0.31	<0.31	<0.19	<0.19	<0.31	<0.19	<0.19	1,1,1,2-Tetrachloroethane
1,1,2,2-Tetrachloroethane	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	1,1,2,2-Tetrachloroethane
Tetrachloroethylene	<0.25	<0.25	<0.25	<0.25	<0.49	<0.25	**2.4**	**2.7**	**2.3**	**2.1**	**0.68**	<0.49	<0.25	<0.25	<0.25	<0.25	<0.25	<0.49	<0.49	<0.25	<0.49	<0.49	**Tetrachloroethylene**
Toluene	<0.20	<0.20	<0.20	<0.20	<0.17	<0.20	<0.17	<0.20	<0.20	<0.20	<0.20	<0.17	<0.20	<0.20	<0.20	<0.20	<0.20	<0.17	<0.17	<0.20	<0.17	<0.17	Toluene
1,2,4-Trichlorobenzene	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	<0.28	1,2,4-Trichlorobenzene
1,1,1-Trichloroethane	<0.23	<0.23	<0.23	<0.23	<0.15	<0.23	<0.15	<0.23	<0.23	<0.23	<0.23	<0.15	<0.23	<0.23	<0.23	<0.23	<0.23	<0.15	<0.15	<0.23	<0.15	<0.15	1,1,1-Trichloroethane
1,1,2-Trichloroethane	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	<0.21	1,1,2-Trichloroethane
Trichloroethylene	<0.22	<0.22	<0.22	<0.22	<0.17	<0.22	**0.27**	**0.35**	**0.28**	**0.31**	<0.22	<0.17	<0.22	<0.22	<0.22	<0.22	<0.22	<0.17	<0.17	<0.22	<0.17	<0.17	**Trichloroethylene**
Trichlorofluoromethane	<0.33	<0.33	<0.33	<0.33	<0.085	<0.33	<0.085	<0.33	<0.33	<0.33	<0.33	<0.085	<0.33	<0.33	<0.33	<0.33	<0.33	<0.085	<0.085	<0.33	<0.085	<0.085	**Trichlorofluoromethane**
1,2,3-Trichloropropane	<0.20	<0.20	<0.20	<0.20	<0.42	<0.20	<0.42	<0.20	<0.20	<0.20	<0.20	<0.42	<0.20	<0.20	<0.20	<0.20	<0.20	<0.42	<0.42	<0.20	<0.42	<0.42	1,2,3-Trichloropropane
Trichlortrifluoroethane	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	<0.22	Trichlortrifluoroethane
1,2,4-Trimethylbenzene	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	1,2,4-Trimethylbenzene
1,3,5-Trimethylbenzene	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	1,3,5-Trimethylbenzene
Vinyl Chloride	<0.18	<0.18	<0.18	<0.18	<0.086	<0.18	<0.086	<0.18	<0.18	<0.18	<0.18	<0.086	<0.18	<0.18	<0.18	<0.18	<0.18	<0.086	<0.086	<0.18	<0.086	<0.086	Vinyl Chloride
Xylene, Total	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	**0.74**	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	<0.24	**Xylene, Total**

* Disinfection By-Products - 80 parts per billion (ppb) is the Maximum Contaminant Level (MCL) for the combined concentrations of these four substances

NOTE: Numbers preceded by a < symbol indicate the substance was not detected; for example, <0.15 means the substance was not found at the 0.15 ppb detection level

MCLG - Maximum Contaminant Level Goal, a public health goal

n/r - not reported